

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 003 Date Jan. 3, 1980
Job Location 120 Pontious Place Valuation \$ 500.00
Owner Mike Reese Address 120 Pontious Place
Contractor Jim Speiser & Sons Telephone No. 599-1846
Address R. R. #2, Napoleon, Ohio
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential Commercial _____ Industrial _____
No. dwelling units _____
New Construction _____ Addition _____ Remodel
Brief Description of Work New 100A overhead service and new circuits.

ISSUED BY R.E. Johnson DEPT. OF BUILDING & ZONING
Building Official

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>9.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____

TOTAL FEES	\$ <u>9.00</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>PAID</u>

JAN 14 1980

CITY OF NAPOLEON
Gold-Inspector

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(please print or type)

003
\$9.00

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name MIKE RAUSE Address 120 Portious Place

Electrical Contractor Jim Spasick Sons Telephone No. 599-5106
604-1846

Address RR #2 Napoleon Ohio

General Contractor _____ Telephone No. _____

Address _____

Location of Project 120 Portious Pl. Cost of Project 500.00

Work Information:

Residential Commercial _____ Industrial _____

No. Units _____
New Service Change _____ Rewiring _____ Additional Wiring NO

Brief Description of Work: NEW 100 A OVERHEAD
SERVICE & 4 NEW CIRCUITS.

Size of proposed Service Entrance 100 Number of new Circuits 4

Type of proposed Service Entrance _____ Underground _____ Overhead

Require Temporary Electric _____ (Yes or NO)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*GROUND-FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE: AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. Art. 210-8 N.E.C.

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date 12-28-79 Applicant's Signature John R. Rouse

MARK
REMODEL

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. _____ Date Jan. 3, 1980
Job Location 120 Pontious Place Valuation \$ 500.00
Owner Mike Reese Address 120 Pontious Place
Contractor Jim Speiser & Sons Telephone No. 599-1846
Address R. R. #2, Napoleon, Ohio

Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential Commercial _____ Industrial _____
New Construction _____ Addition _____ Remodel
Brief Description of Work New 100A overhead service and new circuits.

ISSUED BY _____ DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ <u>9.00</u>
Electrical Permit	\$ _____
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>9.00</u>
LESS FEES PAID	\$ <u>0.00</u>
BALANCE DUE	\$ _____

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND		ROUGH-IN &				FINA'	
Type	Date	By	Type	Date	By	Date	
PLUMBING	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent	
	Building Sewer		Water Piping			Water Heater	
	Water Piping		Condensate Lines			Backflow Prevention	
			Indirect Waste				
						FINAL APPROVAL	
ELECTRICAL	Floor Ducts Raceways		Rough Wiring			Electric Mtr. Clearance <i>3/28/09</i>	
	Conduits & or Cable		Conduits/ Cable			Signs	
	Grounding & or Bonding		Service Panel				
			Subpanels				
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL <i>3/28/09</i>	
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Duct Insulation	
	Ducts/ Plenums		Ducts/ Plenums			Chimney(s)	
			Ventilation Supply			Furnace(s)	
			<input type="checkbox"/> Exhst.			FINAL APPROVAL	
	Location, Set-backs, Esmt(s)		Wall Construction			Fireplace Chimney	
BUILDING	Excavation		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access	
	Footings & Reinforcing		Floor System(s)			Special Insp Reports Rec'd	
	Sub-soil Drain		Roof System			Smoke Detector	
	Foundation Walls		Fire Wall(s)			Demolition (sewer cap)	
	Floor Slab		Roof Cover Roof Drain			Building or Structure	
	FINAL APPROVAL BLDG. DEPT.		—	Certificate of Occupancy Issued		#	

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name REESE

Address 120 PONTIUS PLACE

City State

Approved

Violation

Electrical Contractor J. SPEISER

Remarks:

Code Reference

300
In Kitchen counter top. Pol. of work
not of vent. Reversed polarity
check

Compliance Time

Inspectors Signature

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

