

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 724-77 Issued 5/24/77
date

Job Location 160 Railroad St.
address

Lot NW 1/4 Sec. 13 Nap. Twp.
sub-div or legal discript

Issued By [Signature]
building official

Owner Woods Auto Supply, Inc. 599-4015
name tel.

Address 907 Oakwood Ave.

Agent Self Same
builder-eng.-etc. tel.

Address Same

Description of Use Machine Shop

Residential _____
no. dwelling units

Commercial _____ Industrial XX

New _____ Add'n. _____ Alter _____ Remodel XX

Mixed Occupancy _____

Change of Occupancy XXX

Estimated Cost \$ 1,500.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$35.00	\$15.75	\$50.75
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING	---	---	---
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. <u>0</u> hrs	<u>0</u> hrs	
	Elect. _____ hrs		
TOTAL FEES.....			50.75
LESS MIN. FEES PAID <u>5/18/77</u> <small>date</small>			\$50.75
BALANCE DUE.....			---0---

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
"I-1"	See Site Plan	See Site Plan	Existing	Existing.	0' req'd.
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
40' OK	1 Required.	None	60% OK	None	-----

WORK INFORMATION:

Size: Length 30' Width 30' Stories 1 Ground Floor Area 900sq'

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: _____
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: SEE ATTACHED ADDENDUM:

Date _____ Applicant Signature [Signature] owner-agent

May 23, 1977

ADDENDUM TO PERMIT APPROVAL
WOODS AUTO SUPPLY, INC.
AUTO PARTS AND REPAIR BUILDING
NO. 724-77

Mr. Oliver R. Bishop
City Manager
City of Napoleon
255 Riverview
Napoleon, Ohio 43545

This addendum is attached to and is a part of the plans. All items below shall be performed and will be incorporated into the structure.

1. The hardware for the exit doors shall be Type A or B as classified in Sections 4101:2-73-13 and 4101:2-23-27 of the Ohio Administrative Code.
2. A Type A, B or D exit sign is required at every exit which cannot be readily located or identified as such in an emergency in accordance with Section 4101:2-73-18 of the Ohio Administrative Code.
3. The installation of paneling on the ceiling and sidewalls shall have a fire-resistance rating of one hour in accordance with Section 4101:2-73-19 of the Ohio Administrative Code.
4. The requirement for a toilet room is being waved as specified under Section 4101:2-73-23 of the Ohio Administrative Code because only employees of Woods Auto Supply, Inc. will be working in the building and can use the facilities in the parts sales building.
5. Heating, ventilating and air conditioning systems shall be installed in accordance with Section 4101:2-73-25 of the Ohio Administrative Code.
6. All electrical equipment and lighting installations shall conform to Section 4101:2-73-29, Chapter 4101:2-49 of the Ohio Administrative Code and the latest edition of the National Electrical Code.
7. Fire extinguishing equipment shall conform to Section 4101:2-73-32 and Chapter 4101:2-25 of the Ohio Administrative Code.

Plan approval will be valid only upon signing of the Addendum by the Owner or his authorized representative.



Authorized Signature



Title

City of Napoleon
Engineering Department
P. O. Box 151 - 255 W. Riverview Ave.
Napoleon, Ohio 43545

No. 724-77

Date May 23, 1977

CERTIFICATE OF

- Structural Plan Approval
- Electrical Plan Approval
- Special Plan Approval

Submitted
By:

Woods Auto Supply, Inc.
907 Oakwood Avenue
Napoleon, Ohio 43545

- Architect
- Engineer
- Other

- New
- Addition
- Alteration
- Mixed Occupancy
- Change of Occupancy

NAME AND LOCATION OF JOB

OWNER'S AGENT

Norfolk and Western Railroad Building N-W Corner Oakwood & Railroad Street Napoleon, Ohio 43545	Woods Auto Supply, Inc.
---	-------------------------

TYPE OF CONSTRUCTION (Where Applicable) Wood Frame Construction V-A

O.B.C. Type of Occupancy 4101:2-73 Stories One Basement _____

Inspections shall be called for by the builder 48 hours in advance before work is covered. Final inspection must be made before building can be used or occupied. THIS CERTIFICATE SHALL REMAIN POSTED IN A CONSPICUOUS AND SAFE PLACE UNTIL COMPLETION OF JOB. APPROVED PLANS MUST BE KEPT ON JOB SITE AT ALL TIMES DURING CONSTRUCTION.

Plans, specifications and/or application as described above are hereby approved with addendum.

Date of Approval 5-23-77 ^{1 HR.}

BY: Robert C. Jones PLAN EXAMINER

This approval does not cover the water supply, plumbing and drainage. Plans and specifications for this class of work shall be submitted to the Division of Plumbing, State Department of Health for examination and approval. For approval of pressure piping, contact the Division of Pressure Piping, 2323 W. Fifth Ave., Columbus, Ohio. Zoning for Napoleon is not included in this approval.

