

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Thomas F. Eudy
Address 131 Raymond St
Builder Name Self
Address _____ Tel. _____

Lot Information:

Street No. 131 Raymond St
Lot 25 Subdivision Hollow Ridge 1st
Lot Dimensions _____ Lot Area _____ Sq. Ft.
Yard Set Back: Front _____ Rear _____
Side _____ Side _____

Sidewalk required in accordance with Ordinance
No. _____

Zoning "B" Residence

Building Information:

Residence Commercial _____ Industrial _____
Single _____ Double _____ Multiple _____ New Construction _____ Addition _____ Remodel
Size: Length _____ Width _____ No. of Stories _____
Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
Unfinished Attic _____ Garage _____
Foundation: Piers _____ Full Basement _____ Part Basement _____
Concrete _____ Block _____
Walls: Frame _____ Block _____ Brick _____ Other _____
Electrical Outlets: 120v _____ 240v _____
Plumbing: Fixtures _____ Traps _____ Vents _____ Heating _____ Air Conditioning _____
Additional Information: Electrical to conform to the National Electrical Code
Refer to attached electrical application
Date 2/16/74 Applicant Signature Thomas F. Eudy

Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
Excavation _____ Erecting Frame _____ Roof _____
Footing _____ Electrical Work _____

Comments: _____

Certificate of Occupancy Issued _____

Pink - Engineer

Inspector

Permit No.	<u>84</u>			
Issued	<u>2-16-74</u>			
By	<u>R.H. Bushman</u> Building Inspector			
Estimated Cost	<u>3,000.00</u>			
	Fees	Base	Plus	Total
Construction	<u>Remodel</u>	<u>6.00</u>		<u>6.00</u>
Basement				
Detached Garage				
Plumbing				
Electrical		<u>10.75</u>		<u>10.75</u>
Heating				
Air Conditioning				
Water Tap				
Sewer Tap				
Temporary Electric				
Total				<u>11.75</u>

To convert a garage into a family room & a new elect entrance

CITY OF NAPOLEON
115 W. Main St.
NAPOLEON, OHIO 43545

message

reply

to:

Thomas Erdody

131 Raymond St.

Napoleon, Ohio, 43545

subject Electrical Inspection of 8/22/74, Permit no 84-74

The following conditions were noted and must be corrected before The City can change wiring from 60amp. to 200amp.:

1. the distribution box within the building, wiring below box must be protected say with a piece of plywood.
2. the main service panel outside, nail ground wire to side of building with roofing nails.
3. the main service panel outside, suggest paddle-lock be installed for protection.

corrected and inspected by f.w.f on 9/3/74

Once complied with, contact my office for re-inspection.

date Aug 23, 1974, signed *Don W. Swanson* City Building Inspector date _____ signed _____

SENDER: Mail white and pink copies with carbon intact.

33990, Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

RECEIVER: Reply, retain white copy, return pink copy.

CITY OF NAPOLEON, OHIO
ELECTRICAL PERMIT APPLICATION

OWNER THOMAS L. ERBODY CONTRACTOR SAME
 ADDRESS 131 RAYMOND DR. ADDRESS _____
 LOT NO. 25 ADDITION HELLER SIDLINGER 1ST. TELEPHONE NO. 599-9252

PANEL INFORMATION

GROUNDING INFORMATION

SIZE IN AMPS	NUMBER CIRCUITS	SIZE OF SERVICE WIRE	
No. 1 <u>200</u>	<u>12</u>	<u>000 COPPER</u>	SIZE WIRE <u>#6</u>
No. 2 _____	_____	_____	GROUND ROD ONLY <u>8' Gr. Rod.</u>

COST OF PERMIT FIGURED AS FOLLOWS

<u>ELECTRIC WIRING</u>	<u>COST PER UNIT</u>	<u>NUMBER UNIT</u>	<u>DOLLAR VALUE</u>
One (1) Circuit	<u>\$1.00</u>	<u>1</u>	<u>1.00</u>
Next (9) Circuits	<u>.75</u>	<u>1</u>	<u>0.75</u>
Each additional Circuit	<u>.60</u>		
<u>ELECTRIC HEATING</u>			
Each thermostatical heating zone	<u>1.00</u>		
Electric Furnace (See back of Sheet) Inc. 9 Hot Air Ducts	<u>6.00</u>		<u>3.00 Change</u>
Each additional duct over nine (9)	<u>.75</u>		
<u>ELECTRICAL APPLIANCES</u>			
Electric ranges	<u>1.00</u>		
Range top	<u>1.00</u>		
Oven/Dryer	<u>1.00</u>		
Dishwasher	<u>1.00</u>		
Air Conditioner	<u>1.00</u>	<u>1</u>	<u>1.00</u>
Attic fan blower	<u>1.00</u>		
Room Exhaust Fan	<u>1.00</u>		
Disposal	<u>1.00</u>		
Water Heater	<u>1.00</u>		
Change Entrance (Only)	<u>5.00</u>	<u>1</u>	<u>5.00</u>
<u>GRAND TOTAL (Minimum \$3.00)</u>			
For each additional reinspection trip there will be a cost of \$5.00			<u>10.75</u>

I, the undersigned, states that I am well informed on the current NATIONAL ELECTRIC CODE (National Fire Protection Association) and agree that all wiring, fixtures and electrical appliances will meet the minimum requirements of the above mentioned Code.

Date 7/15/74 Signature Thomas L. Erbody
(Owner or Contractor)