

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 491 Date 8-18-82
 Job Location 1065 Reynolds Valuation \$ --
 Owner Dave Flory Address 1065 Reynolds
 Contractor ~~John Gustwiller~~ Telephone No. ~~395-2201~~
 Address _____
 Electric Contractor John Gustwiller Rt. #7 Defiance 395-2201
 Plumbing Contractor _____
 Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential single Commercial _____ Industrial _____
No. dwelling units
 New Construction _____ Addition _____ Remodel _____
 Brief Description of Work new 100 amp box complete rewire

ISSUED BY Richard L. Hayman Building Official DEPT. OF BUILDING & ZONING

AUG 18 1982

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES OF NAPOLEON

Building Permit	\$ _____
Electrical Permit	\$ <u>19.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>19.00</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>19.00</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING

255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 491 Date 8-18-82
Job Location 1065 Reynolds Valuation \$ --
Address
Owner Dave Flory Name Address 1065 Reynolds
Contractor John Gustwiller Telephone No. 395-2201
Address
Electric Contractor John Gustwiller Rt. #7 Defiance 395-2201
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential single Commercial _____ Industrial _____
No. dwelling units
New Construction _____ Addition _____ Remodel _____
Brief Description of Work new 100 amp box complete revire

ISSUED BY Richard E. Hays Building Official DEPT. OF BUILDING & ZONING

PAID
AUG 18 1982

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES CITY OF NAPOLEON

Building Permit	\$	_____
Electrical Permit	\$	19.00
Plumbing Permit	\$	_____
Mechanical Permit	\$	_____
Demolition Permit	\$	_____
Zoning Permit	\$	_____
Sign Permit	\$	_____
Water Tap	\$	_____
Sewer Tap	\$	_____
Temp. Elec.	\$	_____
Other	\$	_____
TOTAL FEES	\$	19.00
LESS FEES PAID	\$	--
BALANCE DUE	\$	19.00

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND		ROUGH-IN &				FINAL	
Type	Date	By	Type	Date	By	Date	
PLUMBING	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent	
	Building Sewer		Water Piping			Water Heater	
	Water Piping		Condensate Lines			Backflow Prevention	
			Indirect Waste				
ELECTRICAL	Floor Ducts Raceways		Rough Wiring	5/12/88		FINAL APPROVAL Electric Mtr. Clearance	
	Conduits & or Cable		Conduits/Cable			Signs	
	Grounding & or Bonding		Service Panel				
			Subpanels				
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL	
			Refrigerant Piping			Duct Insulation	
MECHANICAL	Ducts/Plenums		Ducts/Plenums			Chimney(s)	
			Ventilation <input type="checkbox"/> Supply			Furnace(s)	
			<input type="checkbox"/> Exhst.			FINAL APPROVAL	
	Location, Set-backs, Esmt(s)		Wall Construction			Fireplace Chimney	
BUILDING	Excavation		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access	
	Footings & Reinforcing		Floor System(s)			Special Insp Reports Rec'd	
	Sub-soil Drain		Roof System			Smoke Detector	
	Foundation Walls		Fire Wall(s)			Demolition (sewer cap)	
	Floor Slab		Roof Cover Roof Drain			Building or Structure	
	FINAL APPROVAL	5/12/88		Certificate of Occupancy Issued		#	
	BLDG. DEPT						

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Dave Flory Address 1065 Arnolds

Electrical Contractor John Gustweller Telephone No. 395-2201

Address RR #7 Defiance

General Contractor _____ Telephone No. _____

Address _____

Location of Project _____ Cost of Project _____

Work Information:

Residential Commercial _____ Industrial _____

No. Units _____
New _____ Service Change _____ Rewiring Additional Wiring _____

Brief Description of Work: new 100 amp box complete
service

Size of proposed service entrance 100 Number of new circuits 14

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric _____ (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 210-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 8-18-82

Applicant's Signature John Gustweller

PERMIT NO. 491
PERMIT FEE \$ 19.00

