



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

June 16, 1992

Mayor
Steven Lankenau

Members of Council
James Hershberger, President
Terri A. Williams
John E. Church
Randy J. Bachman
Dennis L. Fligor
Robert G. Heft

City Manager
Terry Dunn

Finance Director
Rupert W. Schweinhagen

Law Director
Michael J. Wesche

Prosecuting Attorney
Thomas L. Bischoff

Shannon Maassel, Environmental Technician
Clevite Elastomers
Route 424
Napoleon, Ohio 43545

Dear Ms. Maassel:

After reviewing your monthly chemical analysis for wastewater discharged into the cities collection system for the month of May, 1992, I must advise you that you have exceeded the discharge limits for Total Phosphorus. Therefore we are requesting an explanation for this violation and a summary of what actions have been taken to insure that future discharge levels are within acceptable limits. I have enclosed a copy of our limits, for sanitary sewage for your information. If you have any questions regarding this matter, please feel free to contact me at 419-592-8811.

Sincerely;

Roger L. Noblit
Director of Water & Wastewater Plts.

Enclosure

cc: Marc Gerken, City Engineer

Don Engel, Plant Engineer, Clevite Elastomers

1400 E. Riverview
Ave

Commercial & Industrial Wastes

No Commercial or Industrial Wastes of a deleterious nature shall be discharged into the City's Sanitary Sewer System, that prior to mixing with sanitary sewage do not meet the following limitations:

- a. Have a pH greater than 9.0 or less than 6.5 .
- b. Contain Cyanide greater than 0.02 ppm.
- c. Contain more than 1.0 ppm of Hexavalent Chromium.
- d. Contain more than 0.5 ppm of Trivalent Chromium.
- e. Contain more than 5.0 ppm of Nickel as Ni.
- f. Contain more than 2.0 ppm of Zinc as Zn.
- g. Contain more than 50 ppm of Chloroform extractable substances.
- h. Contain more than 0.50 ppm of Copper.
- i. Contain more than 0.01 ppm of Cadmium.
- j. Contain more than 0.3 ppb of Mercury.
- k. Contain more than 0.02 ppm of Lead.
- l. Contain more than 7.0 ppm of Phosphorus.
- m. Contain more than 250 ppm of Suspended Solids.
- n. Contain more than 200 ppm of BOD by weight.

CLEVITE Elastomers
Route 424, Napoleon, Ohio 43545
(419) 592-2055

CLEVITE *Elastomers*

June 12, 1992

Mr. Roger Noblit
Director of Water & Wastewater
City of Napoleon
255 Riverview Ave.
Napoleon, Ohio 43545

Dear Mr. Noblit:

MONTHLY CHEMICAL ANALYSIS

Attached is a copy of the chemical analysis for the wastewater discharged for the month of May, 1992.

If you have any questions or if additional data is required, please call me at 592-2055.

Sincerely,



Shannon Maassel
Environmental Technician

Enclosures (1)

GINOSKO LABORATORIES, INC.

17875 CHEROKEE STREET
HARPSTER, OHIO 43323

TELEPHONE
(614) 496-4051
(614) 496-4571

FACSIMILE
(614) 496-4121

Attn: Mr. Don Engel
CLEVITE ELASTOMERS
Route 424
Napoleon, OH 43545

Date Reported: June 9, 1992

Date Received: June 4, 1992


Laboratory No. 060492-47
Sample Date 06-04-92
Sample I.D. 001
Sample Type: None Given


Parameter	Result	Unit
pH	7.94	S.U
T. Suspended Solids	18	mg/l
T. Phosphorus-P	8.91	mg/l
Cadmium	<1	ug/l
Tri. Chromium	<5	ug/l
Hex. Chromium	<5	ug/l
Copper	<2	ug/l
Lead	<10	ug/l
Mercury	<0.2	ug/l
Nickel	<9	ug/l
Zinc	852	ug/l
B.O.D. 5 DAY	15	mg/l
Cyanide, Total	0.131	mg/l
Oil and Grease	9	mg/l

All analyses are performed in accordance with 40 CFR part 136.

Thank you for this opportunity to serve your organization.

Sincerely,


William A. Pfeiffer, Ph.D.
Director of Operations
Laboratory Analyst Class IV.
Certificate #4-87-37


Coleen M. Baer
Laboratory Director
Laboratory Analyst Class IV
Certificate #4-89-05