



# GRINNELL

## HYDRAULIC DESIGN INFORMATION SHEET

NAME GOULD INC. DATE July 27, 1978  
 LOCATION NAPOLEON OHIO  
 BUILDING \_\_\_\_\_ SYSTEM NO. 1  
 CONTRACTOR MAC-KINNON-PARKER INC. CONTRACT NO. 333920X  
 CALCULATED BY JOHN BOWER DRAWING NO. 2002  
 CONSTRUCTION:  COMBUSTIBLE  NON-COMBUSTIBLE CEILING HEIGHT 27 FT.  
 OCCUPANCY \_\_\_\_\_  
 APPROVING AUTHORITIES FACTORY MUTUAL

SYSTEM DESIGN

NFPA 13:  LT. HAZ. ORD. HAZ. GP.  1  2  3  EX. HAZ.  
 NFPA 231  NFPA 231C: FIGURE \_\_\_\_\_; CURVE \_\_\_\_\_  
 OTHER (Specify) \_\_\_\_\_  
 SPECIFIC RULING \_\_\_\_\_ MADE BY \_\_\_\_\_ DATE \_\_\_\_\_

AREA OF SPRINKLER OPERATION 2500  
 DENSITY 15  
 AREA PER SPRINKLER 120  
 HOSE ALLOWANCE GPM: INSIDE 250  
 HOSE ALLOWANCE GPM: OUTSIDE \_\_\_\_\_  
 RACK SPRINKLER ALLOWANCE \_\_\_\_\_

SYSTEM TYPE  
 WET  DRY  DELUGE  PRE-ACTION  
 SPRINKLER OR NOZZLE  
 MAKE Grinnell MODEL F-950  
 SIZE 1/2 Orifice K-FACTOR 5.56  
 TEMPERATURE RATING 212°

CALCULATION SUMMARY GPM REQUIRED 648 PSI REQUIRED 51 AT TANK MAIN  
 (Specify Location)  
 "C" FACTOR USED: OVERHEAD 120 UNDERGROUND 120

WATER SUPPLY

WATER FLOW TEST	PUMP DATA	TANK OR RESERVOIR
DATE & TIME _____	RATED CAPACITY _____	CAPACITY _____
STATIC PSI <u>67</u>	AT PSI _____	ELEVATION _____
RESIDUAL PSI <u>48</u>	ELEVATION _____	
GPM FLOWING <u>1240</u>		
ELEVATION _____		
	<u>1400 E. Riverview Ave</u>	
		WELL
		PROOF FLOW _____ GPM

LOCATION \_\_\_\_\_  
 SOURCE OF INFORMATION \_\_\_\_\_

COMMODITY STORAGE

COMMODITY \_\_\_\_\_ CLASS \_\_\_\_\_ LOCATION \_\_\_\_\_  
 STORAGE HEIGHT \_\_\_\_\_ AREA \_\_\_\_\_ AISLE WIDTH \_\_\_\_\_  
 STORAGE METHOD: SOLID PILED \_\_\_\_\_ % PALLETIZED \_\_\_\_\_ % RACK \_\_\_\_\_ %

SINGLE ROW  CONVENTIONAL PALLET  AUTOMATIC STORAGE  ENCAPSULATED  
 DOUBLE ROW  SLAVE PALLET  SOLID SHELVING  NON-  
 MULTIPLE ROW  OPEN  ENCAPSULATED

FLUE SPACING IN INCHES  
 LONGITUDINAL \_\_\_\_\_ TRANSVERSE \_\_\_\_\_  
 CLEARANCE FROM TOP OF STORAGE TO CEILING  
 \_\_\_\_\_ FT. \_\_\_\_\_ IN.


HORIZONTAL BARRIERS PROVIDED \_\_\_\_\_

GRINNELL  
 NI.85 GRAPH

CONTRACT NO. \_\_\_\_\_  
 NAME: BOUNT TMC.  
 ADDRESS: NAPOLEON OHIO

SHEET NO. 2 OF 5  
 SYSTEM NO. \_\_\_\_\_  
 DATE: July 24 1978

MULTIPLY SCALE BY 10  
 PSI



CRINNELL FIRE PROTECTION SYSTEMS CO., INC

07/20/78

15:50

PAGE NO 3

K	GPM	TOTAL GPM	PIPE ID	EQUIV FT	FF/L	TOTAL PSI	REF PT	NOTES	
H+W=	120	DENSITY=	.15		AREA=	2500			
CROSS MAIN						10.48	0		
5.56	.6	.6	1.61	10.0	0	10.48	1		
5.56	16.0	16.6	1.61	10.0	.14	10.62	2		
5.56	18.1	36.8	1.61	10.0	.50	11.12	3		
5.56	18.5	55.2	1.61	187.0	19.81	30.93	4	2T = 16	
0	0	55.2	3.26	12.0	.04	30.97	5		
0	55.3	110.6	3.26	12.0	.15	31.12	6		
0	55.4	166.0	3.26	12.0	.31	31.43	7		
0	44.9	211.0	3.26	12.0	.49	31.92	8		
0	30.1	241.1	3.26	12.0	.62	32.54	9		
0	30.4	271.5	3.26	25.0	1.62	34.16	10	T = 15	
CROSS MAIN						10.48	0		
5.56	17.4	17.4	1.61	10.0	.12	10.60	11		
5.56	18.1	35.5	1.61	10.0	.47	11.07	12		
5.56	18.5	53.9	1.61	87.0	8.82	19.89	13	2T = 16	
0	0	53.9	3.26	12.0	.04	19.93	14		
0	54.0	108.0	3.26	12.0	.14	20.07	15		
0	54.2	162.2	3.26	12.0	.30	20.37	16		
0	24.6	186.9	3.26	12.0	.39	20.76	17		
0	-30.1	156.7	3.26	12.0	.28	21.04	18		
0	-30.4	126.3	3.26	12.0	.19	21.23	19		
0	-32.0	94.3	3.26	12.0	.11	21.34	20		
0	-31.5	62.8	3.26	12.0	.05	21.39	21		
0	-31.5	31.3	3.26	12.0	.01	21.40	22		
0	0	31.3	1.61	324.0	12.00	33.40	23	4T = 32	
0	0	31.3	3.26	12.0	.01	33.41	24		
0	31.5	62.8	3.26	12.0	.05	33.46	25		
0	31.5	94.3	3.26	12.0	.11	33.57	26		
0	32.0	126.3	3.26	27.0	.43	34.00	27	T = 15	
COMBINED GPM		397.8			AVE. PSI	34.08			
SPK=	0	0	397.8	4.12	66.0	2.78	36.86	28	E, ALV = 35
ELEVATION		397.8			27.0	11.69	48.55		Base of River
UNDERGROUND									
H+W COEFF.									
140		397.8	6.01	97.0	.49	49.04		LTE, T = 39	
ADDL DEMAND GPM=		250.0							
140		647.8	8.10	525.0	1.52	50.56		T = 35	

ENTER NO OF PIPES TO BE CHANGED IN EACH DIRECTION 24  
ENTER PIPE NOS. TO INCREASE LENGTH 217 34 41 45  
ENTER PIPE NOS. TO DECREASE LENGTH 24 31 38 43  
ENTER DISTANCE BETWEEN SPRINKLERS 210  
ENTER ACCURACY IN PERCENT OF GRID LOSS 72

AVE GRID LOSS= 22.37 PSI POSITION 2

AVE GRID LOSS= 22.70 PSI POSITION 3

AVE GRID LOSS= 22.98 PSI POSITION 4

AVE GRID LOSS= 23.21 PSI POSITION 5

AVE GRID LOSS= 23.35 PSI POSITION 6

AVE GRID LOSS= 23.42 PSI POSITION 7

AVE GRID LOSS= 23.42 PSI POSITION 8

AVE GRID LOSS= 23.33 PSI POSITION 9

ENTER POSITION DESIRED??  
ENTER ACCURACY IN PERCENT OF GRID LOSS 71

AVE GRID LOSS= 23.72 PSI POSITION 7

PEAKING  
Proof

PIPE SIZE	LENGTH OF TRANSFER	FITTINGS	GPM THRU TRANSFER	"PF" THRU TRANSFER	PRI. C.M. REF. PT.	SEC. C.M. REF. PT.	"PF" DIFFERENCE BET. PT.	VARIANCE
1.61	324	4T+32	30.1	11.2	8	17	11.2	0
1.61	↑	↑	30.4	11.4	9	18	11.5	.1
1.61			32.0	12.5	26	19	12.3	.2
1.61			31.5	12.1	25	20	12.1	0
1.61	↑	↑	31.5	12.1	24	21	12.0	.1

TRANSFER PROOFS