

APPLICATION FOR PERMIT TO TAP SEWER

Owner ROY'S BODY SHOP  
ADDRESS 360 E RIVERVIEW  
CONTRACTOR LOW DEYLEN PLBG & HTG FNC  
ADDRESS 116 E CHINTON TEL. 592-4756

NO. SA 0089-88  
201114  
BLDG. PERMIT NONE  
PERMIT FEE \$ 100.00  
STREET BOND NONE  
DATE PAID 12-29-88  
For office use only

LOCATION OF CONNECTION

Street and No. 360 E RIVERVIEW Sanitary  Storm   
Lot No. \_\_\_\_\_ Subdivision \_\_\_\_\_ Size of Tap 4"  
Size and Type of Sewer 4" PVC ALL WORK MUST BE INSPECTED  
Street to be opened-Yes \_\_\_\_\_ No  Opening bond fee set by Engineer \$ NONE  
Street opening agreement approval date NONE

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Date 12-29-88 Signature Arnold Miller  
Owner-Builder-Agent

DO NOT WRITE BELOW THIS LINE

INSPECTION RECORD

Date Inspected 12-88 Size and Type of Sewer 4" SCH 40 P.D.C.  
Location SEE SITE PLAN Depth SEE SITE PLAN Type of Test NONE  
Inspected and Approved by: M. HECKING 12-88  
Inspector Date

Additional information \_\_\_\_\_


Send copy to: \_\_\_\_\_

SKETCH OF INSTALLATION - ON BACK




CITY OF NAPOLEON  
ENGINEERING DEPT.  
255 W RIVERVIEW  
NAPOLEON, OH 43545

JOB ROY'S BODY SHOP  
SHEET NO 360 E. RIVERVIEW  
CALCULATED BY 57 DATE \_\_\_\_\_  
CHECKED BY M. HELBRIG DATE 12-88  
SCALE \_\_\_\_\_





4" Sch. 40  
Drain



Roy's  
Body  
Shop

4" Sch. 40 P.V.C.  
1.5' deep

Existing 4" Drain

M.H.

Grease Trap

C.O.

2.01

3" Vent

Brick Sewer

