

City Of Napoleon
FIELD SURVEY FORM

Premises Address: 464 E. Riverview Company Name: Automatic FEED
Contact Name: Pete Beck Contact Phone No: 592-0050
Service No: 3501 Service Size: 1" Meter No: 47338164 Meter Size: 1" Date Installed: 4-18-97
Type of Inspection: Initial Follow-Up Date of Inspection: 3-26-97 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 12" System Pressure 65-75 psi.
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No *radiant*
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

Sink
Hot water Tank
Eye Wash

FIRE PROTECTION SYSTEMS

System Type: Dry Sprinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

This is Fritz's old service going into new addition

BACKFLOW PREVENTION REQUIREMENTS

1" Febo R.P.A. and expansion Tank already in place, This device is sufficient but needs to be tested