

City Of Napoleon
FIELD SURVEY FORM

Premises Address: 476 E. Riverview Company Name: Automatic Feed
Contact Name: Pete Beck Contact Phone No: 582-0050
Service No: 8018 Service Size: 6" Meter No: none Meter Size: none Date Installed: 6-24-80
Type of Inspection: Initial Follow-Up Date of Inspection: 3-26-99 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 12" System Pressure 65-75psi
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

Ames 6" 3000 SS D.C.D.A. already in place

BACKFLOW PREVENTION REQUIREMENTS

Device here is sufficient, however it needs to be tested

City Of Napoleon
FIELD SURVEY FORM

Premises Address: 476 E. Riverview Company Name: Automatic feed
Contact Name: Pete Beck Contact Phone No: 592-0050
Service No: 9105 Service Size: 2" Meter No: 8679740 Meter Size: 2" Date Installed: 12-26-86
Type of Inspection: Initial Follow-Up Date of Inspection: 3-26-99 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 12" System Pressure 45-75 PSI
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity _____
also radiant heat

INSPECTOR COMMENTS/DIAGRAMS

Steam Jenny w/ Detergent additive
Water filled cutting table w/ additive
radiant Heat + Boiler Heat
Bathrooms
Sprinkler system for yard

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

Water filled cutting Table should have an air gap bracket made to hook
here to when adding water.

1" Feeco P.V.B. in place on sprinkler system
needs to be tested.

BACKFLOW PREVENTION REQUIREMENTS

2" R.P.A. needs to be installed immediately ^{after} ~~before~~ meter, in horizontal
position.
City will upgrade 2" water meter