

CITY OF NAPOLEON

ZONING PERMIT

Zoning Permit No. 0044

Issued 9-10-92

By Brent N. Dammann
Zoning Inspector

Filing Fee \$5.00 Amount Date Paid

Issued To: John Rosebrock/Rupp Rosebrock, Inc. 893-7999

Lot Information:

Street Address 476 East Riverview Automatic Feed

Lot No. Subdivision (or Legal Description)

Lot Dimensions N/A Yard Set Back: Front Rear

Lot Area Sq. Ft. Side

Zoning District I-2 Open Industrial Description of Use Fabrication Manufacturer

Lot Coverage 80% max. Off Street Parking Spaces Required no additional

Height Loading Spaces Required 1

Petition or Appeal Required No PAID

Approved By: Zoning Inspector 9-10-92 Board of Zoning Appeals SEP 11 1992

Date 9/10/92 Applicant Signature [Signature] Owner-Agent CITY OF NAPOLEON

White - Applicant

Pink - Engineering

Yellow - Board of Zoning Appeals

CITY OF NAPOLEON

ZONING PERMIT

Zoning Permit No. 0044

Issued 9-10-92

By Brent N. Demman

Zoning Inspector

Filing Fee \$5.00

Amount Date Paid

Issued To: John Rosebrock/Rupp Rosebrock, Inc. 893-7999

Lot Information:

Street Address 476 East Riverview

Automatic Feed.

Lot No. Subdivision

(or Legal Description)

Lot Dimensions N/A

Yard Set Back: Front Rear

Lot Area Sq. Ft.

Side Side

Zoning District I-2 Open Industrial

Description of Use Fabrication Manufacturer

Lot Coverage 80% max.

Off Street Parking Spaces Required no additional

Height Loading Spaces Required

Petition or Appeal Required No

PAID

Approved By: Zoning Inspector 9-10-92

Board of Zoning Appeals

SEP 11 1992

Date 9/10/92

CITY OF NAPOLEON

Applicant Signature

Owner-Agent

White - Applicant

Pink - Engineering

Yellow - Board of Zoning Appeals



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

476 E. Riverview

September 3, 1992

Mayor
Steven Lankenau

7-464

Mr. John Rosebrock
Rupp/Rosebrock, Inc.
S.R. 24
Liberty Center, OH 43532

Members of Council
Terri A. Williams, President
John E. Church
Michael J. DeWit
Dennis L. Filgor
Robert G. Heft
James Hershberger

Re: Automatic Feed Co.
Zoning Permit

Dear Mr. Rosebrock:

We have reviewed the site plans submitted for the granting of a zoning permit and we have only one (1) comment.

City Manager
Terry Dunn

Your drawing A-1 shows a yard drain that appears to enter the new storm sewer. If this yard drain serves as a floor drain, it must be connected to the sanitary sewers.

Finance Director
Rupert W. Schweinhagen

Per our telephone conversation, the new storm drainage will only serve as a discharge for roof water from the new and existing building.

Law Director
Michael J. Wesche

Respectfully,

Prosecuting Attorney
Thomas L. Bischoff

Marc S. Gerken, P.E.
City Engineer

MSG:rw

cc: Spring Valley Architects, Inc.