

# METER YOKE RELEASE

This document is for the release of one (1) Water Meter Yoke for Residential water service lines.

RELEASE NO. 178

PERMIT NO.                      ISSUED 11/13/95

JOB LOCATION 1030 W. Riverview

- Inside City Limits      ( ) - Outside City Limits

ISSUED BY BND

OWNER Henry Precht

ADDRESS 1030 W. Riverview

CONTRACTOR Mort Cordes

ADDRESS RR#4 Nap.

CONTRACTOR'S PHONE NO. 758-3855

WATER TAP SIZE:  = 1"      ( ) = 1-1/2"      ( ) = 2"

WATER METER s#                     

( ) - New Dwelling       - Existing Dwelling

( ) - Lawn Meter

Water Service Line to be Type (K) Copper or (CTS) Polyethelene Tubing of one inch (1") minimum.

Watts No. 7 Dual check required ( ) = Yes       = No

Water Meter Yoke installation is subject to the following conditions:

- 1.) Must be located in an accessible area.
- 2.) Must be in an area not subject to freezing temperatures.
- 3.) Must be eighteen inches (18") above floor level, not in crawl spaces.
- 4.) Must comply with the mounting criteria and clearances as set forth in DRAWING #04403901.