

City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151 NAPOLEON, OHIO 43545-0151 (419) 592-4010 FAX (419) 599-8393

July 10, 1997

130 W. Riverview

Mr. Jerry Steen

Henry County Solid Waste Management

104 E. Washington St. Suite 301

Napoleon, Ohio 43545

Members of Council Michael J. DeWit, President

Dennis Fligor James Hershberger Glenn A. Miller Travis B. Sheaffer

Donald M. Stange

Mayor

Char Weber Terri A. Williams

City Manager Marc S. Gerken, P.E.

Finance Director Gregory J. Heath

Law Director David M. Grahn

City Engineer
Adam C. Hoff, P.E.

Re. Stairway at recycling trailers Canal Basin

Dear Jerry

The City has received a complaint regarding the condition and the arrangement of the stairways at the Canal Basin recycling center. Specifically the dimensions of the steps and the insecure hand rails.

The minimum tread width for such a stairway is 11 inches and the maximum rise is 7 inches, the height of treads shall be within 3/8" of each other (OBBC regulations). The handrail height shall be between 30 and 38 inches. The handgrip portion of the handrail shall not be wider than 2 5/8". All handrails shall be securely fastened. In your particular situation the top step should be level with the floor of the trailer if practical.

If you have questions or would need assistance regarding the design for rebuilding the stairway, please call.

Sincerely

Dient M. Damman
Brent N. Damman

Zoning Administrator