



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

Mayor
Steven Lankenau

Members of Council
Lawrence Haase, President
Donald Stevens
James Hershberger
Terri A. Williams
John E. Church
Randy J. Bachman

City Manager
Terry Dunn

Finance Director
Rupert W. Schweinhagen

Law Director
Michael J. Wesche

Assistant Law Director
Jeffrey R. Lankenau

November 10, 1989

Mr. Lynn Rausch
1320 West Riverview
Napoleon, Ohio 43545

Re: Permit No. 01722

Dear Mr. Rausch:

Temporary occupancy is granted to Lynn Rausch for the residence at 1320 West Riverview providing that the following items are completed as soon as weather conditions permit:

- #1 Sidewalks are installed as required along the street and right-of-ways.
- #2 Permanent stoops steps & walks are installed at the exterior doors.
- #3 Exhaust fans are installed in the basement and first floor, 1/2 baths.

Sincerely,

Eldon Huber
Building Inspector

EH:skw

Lynn Rausch

Date

LYNN KASH #

3 1/2" x 15" ~~16"~~ LAM BEAM GARAGE DOOR HEADRS
ROOF BEAM

OK

66# x 12' = 720# BEAM WILL CARRY ~~872~~ 907

2x10 SPF FLOOR JOIST OK FIRST FLOOR

2ND FLOOR JOIST 2x10 S.P.F. OK

* SUBMIT TRUSS DIAGRAMS

PROVIDE SOLID

BEAM SUPPORTING FIRST FL WALL + 2ND FLOOR FLOOR

$$1/2 \cdot 17' - 8" = 8' - 10"$$

$$8' - 10" \times 40 \# \text{ P.L.F.} = 360 \#$$

$$\text{WALL } 15 \# \text{ P.L.F.} \times 8' = 120 \#$$

480# P.L.F. ON BEAM

$$480 \times 12 \times 12 \times 12$$

8

103,680

$$\frac{103,680}{1400} = 74.0$$

$$S = \frac{L \cdot d^2}{6} = 85.5$$

3 - #1 S.P. 2x10^s

OR

4 #2 S.P. 2x10^s

YELLOW PINE FLOOR JOIST,