

7-14-97

Drew Dammann - Insp.

Jerry Slany - Contractor



HENDERSON AERIAL SURVEYS INC. 0 40 17 APR. 1991 THE CITY OF NAPOLEON, OHIO P.O. BOX 151, 43545, ENGINEERING DEPT., 419-592-4010, FAX # 599-8



1410

1440 Chesefield

1510

1440

Upstream Manhole

4" CI stub @ 2' F/L

assumed

New sewer pipes here connected to 4" vit w/ 4" SDR35 PVC

assumed

73'

416' @ 3.6'

63.5'

73.2'

36.8'

Sewer was packed full of roots replaced 117 feet of sewer as shown

There is an offset pipe or obstruction in this area, 3" cutter was the largest that would go through

Water Main

12" Sewer main

1530 W. Revenue Ave