



Wood County Building Inspection
One Courthouse Square
Bowling Green, OH 43402
Phone (419) 354-9190 • Fax (419) 373-6786

Commercial Alteration Building Permit

Permit Number: B12-000712
Status: Approved

Date Issued: 09/24/2012

Owner Information
CITY OF NAPOLEON
255 W RIVERVIEW
NAPOLEON OH 43545

Applicant Information
City of Napoleon
255 W. Riverview
Napoleon OH 43545
419-592-4010

Parcel:

Permit Information:
Project Address:
255 WEST RIVERVIEW
PERRYSBURG , OH 43551

Valuation: \$0.00
Total Fee Paid: \$230.23
Total Square Feet: 294.0
Use Group: B

Jurisdiction: Napoleon Corp.

Project Description: Alterations for court records & Engineer's storage room

- Inspection Information:**
1. All inspections require one working day (24 hours) advance notice.
 2. Inspections must be scheduled and approved before covering any work.
 3. Approved plans are required to be on the job site for all inspections.

This permit is issued in reliance upon information submitted by the applicant. The Building Official may suspend or revoke a permit whenever the permit is issued in error, on the basis of incorrect information supplied, or in any violation of any adopted code, city ordinance or regulations. This permit shall become null and void if the work authorized by this permit is suspended for a period of 365 days or is not commenced within 365 days. Work shall not commence until the permit has been issued.

PERMITS ARE NON-REFUNDABLE OR TRANSFERABLE

Issued By: 

Date: 9.24.2012

Wood County Building Inspection

Michael J. Rudey, Chief Building Official

Board of County Commissioners
James F. Carter · Tim W. Brown · Joel M. Kuhlman



One Courthouse Square · Bowling Green, OH 43402 · Phone (419) 354-9190 · Fax (419) 373-6786
buildinginspection@co.wood.oh.us · <http://wcbinspect.co.wood.oh.us>

November 08, 2012

Job No: 12-002131
Permit No: B12-000713
Job Name: CITY OF NAPOLEON
Location: 1775 INDUSTRIAL DRIVE
Twp./Corp.: Napoleon Corp.
Applicant: City of Napoleon - Jon Bisher
Reviewed by: Mark Meyer

APPROVAL WITH CONDITIONS:

Note! Per Section 106.3.1.2 of the Ohio Building Code, the documents as submitted for the above referenced project have been reviewed and found to be either inadequate or in non-compliance with the Ohio Building Code. The submitter shall review the following corrections, make appropriate revisions/additions to the documents and re-submit for review and approval.

If you wish to object to the corrections or stipulations, you must submit a written appeal to the Wood County Building Inspection Department within thirty (30) days. If you have any questions, please contact our office at 419-354-9190.

Conditions:

1. Provide sprinkler plans for the required modifications to the sprinkler system. The plans are to be prepared by an Ohio licensed design professional or licensed sprinkler designer according to Section 106.2 OBC.

White, Lori

From: Zimmerman Tom [tzimmerman@napoleonohio.com]
Sent: Tuesday, November 06, 2012 8:01 AM
To: Building Inspection
Attachments: Approval with Conditions.pdf; Existing Sprinkler plan.pdf

Attached is a re-submittal for permit # B12-000713 for the City of Napoleon 1775 Industrial Dr. please forward these to Mark Meyer and I will call him later today.

Thank you
Tom Zimmerman
Building Official
City of Napoleon OH
419-592-4010

Wood County Building Inspection

Michael J. Rudey, Chief Building Official

Board of County Commissioners

James F. Carter · Tim W. Brown · Joel M. Kuhlman



One Courthouse Square · Bowling Green, OH 43402 · Phone (419) 354-9190 · Fax (419) 373-6786
buildinginspection@co.wood.oh.us · <http://wcbinspect.co.wood.oh.us>

September 24, 2012

Job No: 12-002131

Permit No: B12-000713

Job Name: CITY OF NAPOLEON

Location: 1775 INDUSTRIAL DRIVE

Twp./Corp.: Napoleon Corp.

Applicant: City of Napoleon - Jon Bisher

Reviewed by: Mark Meyer

APPROVAL WITH CONDITIONS:

Note! Per Section 106.3.1.2 of the Ohio Building Code, the documents as submitted for the above referenced project have been reviewed and found to be either inadequate or in non-compliance with the Ohio Building Code. The submitter shall review the following corrections, make appropriate revisions/additions to the documents and re-submit for review and approval.

If you wish to object to the corrections or stipulations, you must submit a written appeal to the Wood County Building Inspection Department within thirty (30) days. If you have any questions, please contact our office at 419-354-9190.

Conditions:







- 1. Provide electrical and mechanical plans and obtain the permits.**
- 2. Provide sprinkler plans for any required sprinkler modifications.**

Project Name: Proposed Finance Addition	Scale: 1"=3'
Drawn: Mark B. Schmitt	Approved: Chad E. Lutz
Checked: [Blank]	Reviewed: [Blank]
Date: [Blank]	Revision: [Blank]
Drawn By: [Blank]	Checked By: [Blank]

City Of Napoleon Operations Building
 Existing Finance Storage Addition
 Engineering Department
 155 West Franklin Avenue
 Napoleon, Ohio 43445
 Phone: (419) 562-4100
 Fax: (419) 569-8333

Plan Prepared By: [Blank]
 Director Of Public Works
 City Of Napoleon
 Engineering Department
 Chad E. Lutz, P.E., P.S.
 License No. [Blank]

Project No. [Blank]
 Date: [Blank]
 Revision: [Blank]



NOTE:
 Sprinkler Work To Be Performed
 By City Of Napoleon Employees
 As Per ORC 3737.65 (B) - Except
 For Public And Private Mobile Fire
 Trucks, No Person Shall Service, Test,
 Repair, Or Install For Profit Any Fire
 Protection Or Fire Fighting Equipment
 Without A Certificate Or A Provisional
 Certificate Issued By The Fire Marshal.

Existing Finance / Court Records

Finance/Court
Records