

Nº 62878

OHIO DEPARTMENT OF INDUSTRIAL RELATIONS
DIVISION OF WORKSHOPS AND FACTORIES
220 Parsons Ave., Columbus, Ohio 43215

County Henry

CERTIFICATE OF PLAN APPROVAL

Date Jan. 16, 1970 Type of Package:..... Env. Roll

Submitted City of Napoleon
Napoleon, Ohio
43545
by Owner:

Architect #1897
 Engineer Sansenbacher, Miller & Scott, Ltd.
 Other 3023 Sylvania Avenue
 New Toledo, Ohio 43613
 Addition
 Alteration 419-475-4623

NAME OF JOB OR PROJECT AND LOCATION

OWNER'S AGENT

Alterations to City Building (Office) Front at S. R. 424 Napoleon, Ohio 43545	Sansenbacher, Miller & Scott, Ltd. 3023 Sylvania Avenue Toledo, Ohio 43613 419-475-4623
---	---

TYPE OF CONSTRUCTION

Fireproof I-A, I-B
Noncombustible II A, II B, II C
Type of Occupancy BB-67 Stories --- Heavy Timber III
Basement --- Ordinary IV-A, IV-B
Wood Frame V-A, V-B
Estimated Cost \$75,000.00

OUTSIDE DIMENS. EACH FLOOR	SQ. FT.-FLOOR AREA
Basement	
First	
Second	
Third	
Fourth	
Fifth	
TOTAL SQUARE FEET	Alteration

FEE PAID	
@ \$20.00 per structure	\$ 20.00
@ \$1.10 per 100 Sq. Ft.	\$
Total	\$ 20.00

**PLACE THIS COPY
ON JOB SITE**

RECEIVED
MAR 11 1970
WILL LANZER CO.

As per attached addendum

INSPECTIONS shall be called for by the Contractor 48 hours in advance for the following: First, when footings are ready to pour. Second, when building is framed or ready for lath. Electric Wiring and Heating must not be covered until approved by the Inspector. Final inspection must be made before the building can be occupied.

CERTIFICATE OF PLAN APPROVAL SHALL BE AND REMAIN POSTED IN A CONSPICUOUS AND SAFE PLACE UNTIL COMPLETION OF JOB. PLANS APPROVED BY THIS DIVISION MUST BE KEPT ON JOB SITE AT ALL TIMES DURING CONSTRUCTION. Ref. BB-3-22.

INSPECTOR'S REPORT: Footings _____
Ready for Lath _____
Final Inspection _____

In requesting inspections, you will contact _____
Plans and specifications submitted and as described in the above application are hereby approved.
Date of Approval Jan. 15, 1970

District Inspector Robert L. Richardson
Box 45,
Farmers, Ohio 43520
Address _____
Telephone No. 419-658-2514

William H. Kremer
Chief of Division

BY: Seth T. Bentley, Arch.

HENRY COUNTY
January 15, 1979

ADDENDUM TO PLAN APPROVAL NO. 62,878

Sausenbacher, Miller & Scott, Limited
3023 Sylvania Avenue
Toledo, Ohio 43613

Alterations to City Building (Office)
Front at S.R. 424
Napoleon, Ohio 43545
Henry County

This addendum sheet is being attached to and is a part of the approved plans. All items listed below will be incorporated into the structure when completed:

1. Combustion type appliances will not be installed in attics or crawl spaces unless they are of a type that has been approved specifically for such installation. Section HB 47-29 of the OBC.
2. Exit signs will conform to Section HB 67-18 of the OBC.
3. All offices without windows; if natural ventilation is used exclusively, the total area of openings affording ventilation for a space shall be not less than 5% of the floor area of the space or provide mechanical ventilation sufficient to produce not less than six air changes (circulated inside air) per hour and provide an outside air supply of not less than four cubic feet per minute per occupant and an equal amount shall be exhausted. (Sections HB-27-15 and HB-47-15 of the OBC).
4. Electrical wiring, equipment and installation will conform to Chapter HB 49 of the OBC and the National Electrical Code.
5. Hardware for exit doors shall be Type "A" or "B". Locks for doors directly to the outside may be Type "C" where conditions are as follows:
 - a. The use of a key shall not be necessary to permit egress during business hours.
 - b. A permanent type sign, in clear lettering not less than 1/8" in height and reading "THE OPENING OF THIS DOOR FROM THIS SIDE SHALL NOT REQUIRE THE USE OF A KEY DURING BUSINESS HOURS", shall be attached. (Section 67-13 of the OBC).

Failure to return this addendum sheet properly executed within ten (10) days after the date of the plan approval, will result in action by way of revocation of plan approval.

STB:mt
cc: Richardson

