October 13, 1975

Mr. Wayne A. Wolford, AIA Holland Theatre Building Bellefontaine, Ohio 43311

Attention: Wayne Wolford

Re: Napoleon Fire Station
Building Permit No. 96-74

Dear Mr. Wolford:

I am in receipt of your letter of October 3, 1975 concerning issuing of a Certificate of Occupancy. As of October 9, 1975, the following conditions have not been corrected: Installation of directional exit light in hall 202 at the top of the stairway and installing a glass window in the South exterior door in the Apparatus Room. Because of this, I am only authorized to issue at this time a Temporary Certificate of Occupancy for substantial conformity with the codes. Upon completion of the total project, please notify the Engineering Department for re-inspection. This Temporary Certificate of Occupancy expires in thirty days (30) from the time of this notice, upon which time, if additional time is required to correct the above condition, a written request explaining the circumstances must be submitted to my office for approval.

Mr. Norman Howes, Electrical Inspector, has removed the citation relative to the emergency system on the basis of City of Napoleon Resolution No. 1258, where by the City Council has accepted all liability.

When the building complies with all codes, I will be authorized to issue a permanent Certificate of Occupancy as set forth in City Zoning Ordinance No. 1104, Section 85.49.

If you have any further questions, please feel free to contact me at the City Building or phone 419-592-4010.

Very truly yours,

Thomas W. Terranova Building & Zoning Inspector Engineering Department

TWT/cv

cc: Mr. Robert Jones, Chief Building Official

cc: Robert Prentiss

cc: Roy Dorsey

O GOE 3 179 No. Upon completion of establishing the final grade Substantial qualifications of occupancy of the site sproyide one of the approved methods and should be so preserved. This is a valuable record for owner or lessee permission is hereby granted to occupy such building in compliance wth such legal use and occupancy as authorized under the provisions of the ordinances of the City of Napoleon. Owner of Property that construction is completed and health laws and ordinances and with the provisions of the Zoning Ordinance. of handling storm water from downspouts in accordance with Ord. No. 464 Issued to Location of Occupancy This certificate is issued by the City Building Inspector, as provided by law, and is to certify This is to certify that the Building or Land as 19th The Mayor of NapoleonGB.....General...Business. W. Riverview Ave. (Fire Station) City of Napoleon day of I I I I CERTIFICATE OF OCCUPANCY December, substantially CITY OF NAPOLEON ENGINEERING DEPARTMENT DIVISION OF INSPECTION 19 75 in conformity with the approved plans Signed A herein described complies with all the building Address Bldg. Permit No. 96-74 Parking Garage & Sleeping Occupancy Quarters for Transients (BB-55 & BB-73) of O.B.C. Address City Building Inspector W. Riverview Ave. W. Riverview Ave., Napoleo avois 0.B.C.