

City of Napoleon Inspection Form

Permit #002331

Date Issued: 08-16-2004

Job Location: 600 ROHM DR

Owner: MCDOUGLE, LARRY

Owner Phone: 13378

Contractor:

Contractor Phone:

Work Description: ME

Plumbing: UNDGR _____ RGHIN _____ FINAL _____

 SEWER INSP _____

Mechanical: UNDGR _____ RGHIN _____ FINAL _____

 FURNACE REPLAC 8-18 AIR COND _____

Electrical: UNDGR _____ RGHIN _____ FINAL _____

 SEVR UPGR _____

Building: Site _____ FTG _____ FNDDT _____

 STRU _____ ROOF _____ EXT _____

 VENT _____ ACCES _____ EGRS _____

 SMKDT _____ FINAL _____

 ISSUE TEMP OCCUP _____ ISSUE OCCUP _____

STGE Shed: SITE _____ FINAL _____

Sign: FTG _____ FINAL _____

Fence: SITE _____ FINAL _____

DRIVEWAY: _____ SIDEWALK: _____

MISC INSP: _____

NOTES:

INSPECTORS INITIALS: BNP

8-9-93

600 Rohm Dr.
Whirlpool furnace
Model - WUGE105AG01
Serial# H-95153564

Calling P & H to repair & replace
parts + venting.

1. Pressure switch
bypassed.
2. Improper venting
not designed for horz.
wrong type of vent pipe.
3. Blower door switch
removed