

HINKLE AND PAETH, ARCHITECTS

800 CROGHAN STREET • FREMONT, OHIO 43420

REGISTRATION NOS. ROBERT W. HINKLE 2346 - NORMAN L. PAETH 3552

February 18, 1965

Mr. Carl W. Ingle, Building Inspector
Napoleon, Ohio

Re: Addition to Brillhart Elementary School,
Napoleon, Ohio.

Dear Sir:

We received the approved drawings of the subject project today, minus the specifications.

We have asked the Contractor to furnish test borings in the locations shown on the Plot Plan, on Drawing No. 1.

We have also asked the Contractor to repair the cracks on the east end wall of the present class room wing. These cracks were caused by the lugs welded to the ends of the beams spanning the class room windows. This condition is to be corrected.

Mr. William Schuller, our Structural Engineer, from Toledo, has designed the footings for a soil pressure of 3,000 pounds per square foot, which we feel is quite adequate.

Thank you for calling this matter to our attention, and if you have any further questions or suggestions, please contact us.

Very truly yours,

HINKLE AND PAETH, ARCHITECTS

Robert W. Hinkle

Robert W. Hinkle

RWH/ns

From

CITY OF NAPOLEON
City Hall - 115 W. Main St.
Napoleon, Ohio 43545

PLEASE RETURN THIS
MESSAGE REPLY
TO

To

Hinkle + Paeth, Architects
800 Croghan St
Fremont, Ohio 43420

DATE
Feb 22, '65
SUBJECT

Message

Reference to your letter of February 18th on the school specifications.

We have the copy here and you may pick them up on your next ~~trip~~ trip to Napoleon.

Thank you.

A E Taylor
SIGNED

Reply

DATE _____

SIGNED _____

ORIGINATOR - DETACH THIS PART - FORWARD BALANCE OF SET INTACT

ORIGINATOR FOLD MARKS

ADDRESSEE FOLD MARKS