

Certificate of Occupancy

Wood County Building Inspection

Address:
HENRY COUNTY SENIOR CENTER
 201 ROHRS STREET
 NAPOLEON, OH 43545
 County: Henry

Stipulations, Conditions, & Variances:
 New Senior Center Building. All Inspections Completed. Occupancy Approved.

Approved As:

Use Groups:	Occupancy Description:
Primary A-3	Senior Center
Accessory 0	
Accessory 0	
Accessory 0	
Mixed Use 0	

Attached Floor Plan:

Construction Type: 2B

Sprinklers

System Type: NFPA 13
Standpipe: Demand:
 Demand:

Location: Throughout

Specific Hazards: All Fire Alarm and Fire Sprinkler Systems are required to be monitored, tested and certified annually for this Occupancy Approval to remain valid.

This Certificate represents an approval that is valid only when the building and its facilities are used as stated and is conditional upon all building systems being maintained and tested in accordance with the applicable Ohio Board of Building Standards rules and applicable equipment or systems schedules. This certifies conformance with Chapters 3781 and 3791 of the Ohio Revised Code and the applicable provisions of the rules of the Ohio Board of Building Standards.

OBC Ed. 2011 OMC Ed. 2011 OPC Ed. 2011

Health and Safety OBC Section 111.1

Plan Approval/Building Permit No: B16-000952

Date: 12/15/2017

Chief Building Official:

Michael J. Rudey

