

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Earl E. Shasteen
 Address 320 Rohrs St.
 Builder Name Standard Plumbing & Heating Co.
 Address N. Scott St. Tel. 596-5906

Lot Information:

Street No. 320 Rohrs St.
 Lot #13 Subdivision Spring Wells 1st. 488
 Lot Dimensions _____ Lot Area _____ Sq. Ft. _____
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Zoning "A" Intended use of Building: Installing to the existing dwelling a new 23,000btu. air-conditioning unit.

Building Information:

Single Double _____ Multiple _____ New Construction _____ Addition _____ Remodel
 Size: Length _____ Width _____ No. of Stories _____
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical: Wiring 1-circuit Electric Heating --- Electrical Appliances ---
 Plumbing: Fixtures or Traps _____ Warm Air Heating _____ Hot Water Heating _____

Additional Information: This permit requires compliance with the attached letter No. 276-75L and the attached addendum marked exhibit "A" and made a part here-of.

Date 11/13/75 Applicant Signature Earl E. Shasteen
 Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work Inspected & Approved By Howes 6/5/75
 Comments: Note: Installed informed to install seal-tight for wiring outside.
 Certificate of Occupancy Issued _____

Permit No. 276-75
 Issued 5/27/75
 By James W. Howes
 Building Inspector
 Valuation \$1,000

| Fees | Base | Plus | Total |
|-----------------|---------------|-----------|---------------|
| Construction | -- | -- | -- |
| Plumbing | \$3.00 | -- | \$3.00 |
| Electrical | \$3.00 | -- | \$3.00 |
| Heating | | | |
| Water Tap | | | |
| Sewer Tap | | | |
| Temporary Elec. | | | |
| TOTAL | \$3.00 | -- | \$3.00 |

CITY OF NAPOLEON
Engineering Department
255 Riverview Avenue
NAPOLEON, OHIO 43545

| | |
|---------------------------------------|--|
| DATE May 27, 1975 | JOB NO. Permit No. 276-75 |
| PROJECT Installation of A/C system | |
| LOCATION 320 Robrs St. | |
| CONTRACTOR Std. Plb. & Htg. Co. | OWNER Shasteen |
| WEATHER _____ | TEMP. $^{\circ}$ at _____ AM $^{\circ}$ at _____ PM |
| REVISIONS/NOTES Addendum To Permit | |

TO Standard Plumbing & Heating Co.
N. Scott St.
Napoleon, O.

THE FOLLOWING WAS NOTED:

Ordinance No. 1116, Section 7.4, Does require air conditioning systems to be inspected & approved before using.

- Subject ^{to} approval of both the Building and Electrical Inspector.

Note:

Electrical Inspector available for inspections every Thursday from 1:00 PM to 5:00 PM.
Call Engineering Dept. to set up inspection.

Phone No. 592-4010

Inspected & Approved By Hours 6/5/75
Not: Installed returned to ~~reject~~ ^{right} Permit No. 276-751

FIELD REPORT

COPIES TO Std. Plb. & Htg. Co. & on record with Permit No. 276-75

SIGNED James W. Linnora
Building Inspector