



September 24, 1982

Mr. Richard G. Hayman
Building Commissioner
255 Riverview Ave.
Napoleon, Ohio 43545

re: Bonded Station
Railroad & Scott
Napoleon, Ohio

1005
Scott
St.

Dear Mr. Hayman:

To reply to your letter of 9-23-82:

1. Want to catch the water off the canopy so as to protect our customers. If the drain on Railroad is not capable of receiving the run-off we can rebuild it, or go to some other outlet. Perhaps we might have to meet at job site to make a determination.
2. Canopy footings will be 4' x 4' x 4' as per sheet 4A.
3. Back at the existing building line the canopy will have a 14' clearance. As you move away from the building this increases to 15'-0".
4. The entire canopy is steel.
5. Our canopy is non-combustible. As it so happens, in applying for a State Permit, last week for another job, this question came up, and because we are non-combustible, plus there is no plastic, we were allowed to overhang the building.

All our new work will meet the applicable codes, and should we find any violations in the existing building, it will be corrected.

Thank you for your help, will have a check issued and sent to you under separate cover.

Sincerely,

A handwritten signature in blue ink, appearing to read "J. D. Bunn".

J. D. Bunn
Director of Construction

cc: Tom Hiegel

js