

City Of Napoleon

FIELD SURVEY FORM

Premises Address: 1074 N. Scott Company Name: Super Car Wash
 Contact Name: Ed Sickmiller Contact Phone No: 592-9213
 Service No: 94180 Service Size: 2" Meter No: 31900637 Meter Size: 2" Date Installed: 12-20-94
 Type of Inspection: Initial Follow-Up Date of Inspection: 12-10-97 Inspector Name: Charlie
 Type of Use: Industrial Commercial Residential Water Main Size: 8" System Pressure 65-70 psi
 Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
 If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
 Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
 Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
 Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
 Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity see comments
 → gas radiant heater

INSPECTOR COMMENTS/DIAGRAMS

1- Stainless steel reservoir w/4 compartments containing Detergents + waxes
 4- 1000 psi pumps for Hand washers
 2- 1100 psi pumps for Automatic wash
 2- 350 psi pumps for Spot Free rinse Automatic wash
 1- 400 psi pump for Spot Free rinse Hand wash
 2- 30-50 psi pumps for pre-soak Automatic wash
 1- 30-50 psi pump for pre-soak ~~Hand~~ Hand wash
 boiler to heat floor w/anti-freeze, automatic make up fill
 boiler heat for Car Wash water, no chemicals added

2 Large Water Softeners
 Reverse Osmosis System

FIRE PROTECTION SYSTEMS

System Type: Dry Sprinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
 Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
 Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

already has a Watts 909 R.P.A 2" serial # 272092 installed 12-20-94
 also have a watts #7 Dual Check on feed line for Toilet, sink, + garden hose, 3/4" model 702-2
 Tested 10-9-97 by below noted Tester, need to obtain copy of Test + Testers Certification

BACKFLOW PREVENTION REQUIREMENTS

Dependable Backflow Service
 510 Pershing
 Galion, Ohio 44933
 Ray Palmer
 419-468-8210

what you have already meets requirements

Water Dist. - White

Customer - Canary

Building Dept. - Pink