

# City of Napoleon

## BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 1108 N. Scott St ZIP: 43545  
 Business Name: Pioneer Quick Lube

"Potable"

### DEVICE INFORMATION

Type (circle one) **RP** DC VB RPDA DCDA

Manf/Model: Watts 909 Size: 3/4" Serial No. 412396

Location of Device: N.E. Corner basement

Type of Test: Differential Gauge  Sight Tube

Outlet valve holding RP <input type="checkbox"/> DC <input type="checkbox"/> failed RP <input type="checkbox"/> DC <input type="checkbox"/>	Reduced Pressure Assembly ↓			Pressure Vacuum Breaker	
	Double Check Valve ↓		Relief Valve ↓	Air Inlet	Check Valve
	1st Check	2nd Check			
Test Results <i>Fail</i>	DC _____ psi  RP <u>6.0</u> psi <i>Leaked</i>	DC _____ psi	opened at <u>4.0</u> psi  did not open <input type="checkbox"/>	opened at _____ psi  did not open <input type="checkbox"/>	held at _____ psi  leaked <input type="checkbox"/>
Date: <i>3-31-04</i>	Pass <input type="checkbox"/> Failed <input checked="" type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials	<i>Cleaned. SEAT &amp; Seal.</i>				
Test After Repairs <i>Pass</i>	DC _____ psi  RP <u>7.8</u> psi	DC _____ psi  RP <u>7.0</u> psi <i>OK</i>	opened at <u>4.2</u> psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date: <i>3-31-04</i>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: Douglas L. Seely Certification No. 2539  
 Owner/Representative Signature: Lynn Conyer Mgr.