

# METER YOKE RELEASE

This document is for the release of **one (1)** Water Meter Yoke for Residential water service lines.

RELEASE NO. 220

PERMIT NO. 3942

ISSUED 10-10-96

JOB LOCATION 1108 N. Scott

- Inside City Limits      ( ) - Outside City Limits

ISSUED BY [Signature]

OWNER Pioneer Quick Lube

ADDRESS 2510 West W-61 Gladwin, MI 48624

CONTRACTOR FED Corp

ADDRESS Same

CONTRACTOR'S PHONE NO. 517 426-6631

WATER TAP SIZE:  = 1"      ( ) = 1-1/2"      ( ) = 2"

WATER METER s# \_\_\_\_\_

- New Dwelling      ( ) - Existing Dwelling

( ) - Lawn Meter

\* Double check valve assembly required  
Water Service Line to be **Type (K) Copper or (CTS) Polyethelene Tubing of one inch (1") minimum.**

Watts No. 7 Dual check required ( ) = Yes      ( ) = No

**Water Meter Yoke installation is subject to the following conditions:**

- 1.) Must be located in an accessible area.
- 2.) Must be in an area not subject to freezing temperatures.
- 3.) Must be eighteen inches (18") above floor level, **not in crawl spaces.**
- 4.) Must comply with the mounting criteria and clearances as set forth in **DRAWING #04403901.**