

THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419)592-4010

Plumbing Permit

Permit Number: PL2008-62

Page 1 of 1

Printed: 10/24/2008

ADDRESS: *1400 Scott St. suite 400*

Applicant

Name: MTC Properties
Address: 7635 Chestnut Ridge Ln

Approval Date: 10/24/2008
419-445-0000

Owners

Name: MTC Properties
Address: 7635 Chestnut Ridge Ln
Maumee, OH 43537

Phone: 419-445-0000

Contractors

Contractor Type: General Contractor

Name: Rupp Rosebrock
Address: 7464 US 24

Liberty Center, OH 43532

Phone: 419-533-7999

Fees and Receipts:

Number	Description	Amount
FEE2008-738	Water 5/8" meter	\$350.00

Total Fees: \$350.00

RCPT2008-439

\$350.00


Total Receipts: \$350.00

water meter for Dollar General

APPLICANTS SIGNATURE: _____ DATE: _____

REMINDER: YOU MUST CALL (419)592-4010 FOR AN INSPECTION

SCANNED





CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT
255 West Riverview Avenue, P. O. Box 151 Napoleon, OH 43545
Telephone: 419/592-4010 Fax: 419/599-8393
www.napoleonohio.com

WATER METER YOKE RELEASE FORM

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" WATER METER YOKE ASSEMBLY
(Please pickup at City Operations Department 1775 Industrial Drive.)

Permit Number: pl2008-62
Date Issued: 10/24/2008

Job Location 1400 Scott St. Suite 400

Owner: MTC Properties
Address: 7635 Chestnut Ridge Ln

Phone: 419-445-0000

Contractor: Rupp Rosebrock
Phone: 419-533-7999

Water Tap Size: 1" 1 1/2" 2" Other: _____
Water Meter Yoke Size: 5/8" 3/4" 1" Other _____
New Structure: Existing Structure: Lawn Meter:

WATER SERVICE LINE TO BE TYPE "K" COPPER OR "CTS" POLYETHELENE TUBING OF 1" MINIMUM SIZE.

Backflow Device Required? Yes No
Type of Backflow Required: _____

Water Meter Yoke Installation is subject to the following conditions:

1. Must be located in an accessible area.
2. Must be in an area which is not subject to freezing temperatures.
3. Must be at least 18" above floor level (no crawl space installations.)
4. Must comply with minimum mounting requirements (drawings available).

Issued By: _____ Received By: _____

1 Copy to: Building Dept, Water Dept.