

FIELD CORRECTION NOTICE

LOCATION 1406 Scott Street North

PERMIT NO. 2-231

ISSUED TO Marcos Pizza
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO SITE (TIM BLAKEMAN) MANAGER

110-14-B; 336-3

Upon inspection, violations of the 1984 NEC Sec. 400-9 ; 500-1 were in evidence.

The following orders are hereby issued for their correction: Circuit feeding electrical portable sign

shall be GFCI protected. Splices shall be made in a junction box (change of

conductor). NMB Cable not approved for current use. Flashing lights

are prohibited.

CONDUCTORS

SIZE OF

SIZE