

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 179-78 Issued 10-17-78
date

Job Location 1410 Scott St.
address

Lot in SW 1/4 Sec. 12 Nap. Twp.
sub-div or legal discript

Issued By L.E. Johnson
building official

Owner Merle Franz & John Glick
name tel.

Address 127 W. Washington St.

Agent Wickes Buildings 592-0966
builder-eng.-etc. tel.

Address PO Box 62 Nap. Ohio

Description of Use Warehouse Add'n.

Residential _____
no. dwelling units

Commercial XXX Industrial _____

New _____ Add'n. SXX Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 30,000.00

	FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING		\$35.00	\$76.80	\$111.80
<input checked="" type="checkbox"/> ELECTRICAL		18.00	35.20	53.20
<input type="checkbox"/> PLUMBING				
<input type="checkbox"/> MECHANICAL				
<input type="checkbox"/> DEMOLITION				
<input checked="" type="checkbox"/> ZONING		0	0	0
<input type="checkbox"/> SIGN				
WATER TAP				
SEWER TAP				
TEMP. ELECT.				
ADDITIONAL PLAN REVIEW	Struct. _____ hrs _____ Elect. _____ hrs _____			
TOTAL FEES.....				\$165.00
LESS MIN. FEES PAID _____ <small>date</small>				0
BALANCE DUE.....				\$165.00

ZONING INFORMATION

district "PB"	lot dimensions	area	front yd	side yds	rear yd
		SEE SITE PLAN	n/a	10' S OK	Min. 10'
max hgt OK	no pkg spaces no additional	no ldg spaces	max cover OK	petition or appeal req'd Conditional use	date appr 9-26-78

WORK INFORMATION:

Size: Length 96' Width 66' Stories 1 Ground Floor Area 6336sq'

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: Additional circuits.
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: CALL FOR INSPECTIONS MARKED ON ATTACHED SHEET:

Date 10/25/78 Applicant Signature [Signature]
owner-agent

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN			FINAL					
	Type	Date	By	Type	Date	By	Type	Date	By			
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/ Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring	11-9-78	NH	<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)			Special Insp Reports Rec'd			FINAL APPROVAL BLDG. DEPT.		
			Roof System						Certificate of Occupancy Issued			
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					
	<p>4" oct. Boxes to be fastened securely to bldg structure - 376-13 NEC</p>											
	<p>② - Cis fan wired with ext cord. 400-8 NEC</p>											
	<p>other appliances wired with ext cord. 400-8 NEC</p> <p>Temp. wiring for 90 days only. Cords not intended in lieu of fixed wiring</p>											

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

STRUCTURAL PLAN APPROVAL
(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA.
FOR ENGINEERING OFFICE USE ONLY.

App. No. ~~178~~ 179-78

Date Received 10-9-78

Received By R.E.J.

Estimated Cost \$30,000

Minimum Fees

A. Structural \$35.00

B. At \$1.20 Per 100 Ft.² 76.80

A. plus B. \$111.80

1. Owner's Name Meade Cozz & John Glick

Address 127 W. Washington

Napoleon Tel. 592-0901 (Glick)

2. Owner's Agent or Submitter

Walter Blye

Address Box 62

Napoleon Tel. 592-0966

3. Plans Prepared By:

A. Architect

B. Engineer

C. Other

4. Name of Job and Description of Building, Store, Church, Etc.

Storage Building for Cozz & Glick

5. Location of Project: Robert 1410' 11' Scott 1/2 Napoleon Zone:

Lot # Subdivision Section

Yard Set Back: Front Rear

Side Side

6. Building Information:

Commercial Industrial New Construction

Addition Remodel

Size: Length 96 Width 66 No. of Stories ONE

Total Square Ft. Per Floor 6336

7. Additional Information: Bldg shall be constructed within the side

setback lines approved by the City of zoning officials 9/26/78

Signature of Applicant Date 10-9-78

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

ELECTRICAL PLAN APPROVAL

(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA
FOR ENGINEERING OFFICE USE ONLY.

App. No. 179-78

Date Received 10-9-78

Received By R.E.F.

Estimated Cost 30,000

Minimum Fees

A. Structural \$18.00

B. At 55¢ Per 100 Ft.² 35.20

A. plus B. \$53.20

1. Owner's Name Mad Fenz & J. Clark

Address 127 W. Michigan

Tel. 592-0211 (Clark)

2. Owner's Agent or Submitter

Address Box 62

Tel. 592-0966

4. Name of Job and Description of Building, Store, Church, Etc.

5. Location of Project: R.I.D. Zone: Scott 1/2 Block

Lot # Subdivision Section

6. Building Information:

Commercial Industrial New Construction

Addition Remodel

7. Size: Length 76 Width 66

Total Square Ft. Per Floor 26336

8. Size Service Entrance 100 Amp

9. All electrical wiring shall be installed in accordance with the National Fire Protection Association, Bulletin No. 13, "National Electrical Code". All wiring shall also conform to the requirements of the Ohio Building Code for the occupancy indicated.

10. Additional Information:

Signature of Applicant [Signature] Date 10-9-78

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

STRUCTURAL PLAN APPROVAL

(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA.
FOR ENGINEERING OFFICE USE ONLY.

App. No. ~~178~~ 179-78

Date Received 10-9-78

Received By R.E.J.

Estimated Cost \$30,000

Minimum Fees

A. Structural \$35.00

B. At \$1.28 Per 100 Ft.² 76.80

A. plus B. \$111.80

1. Owner's Name Mark Feenz & John Glick

Address 127 W. Washington

Napoleon Tel. 972-0901 (Glick)

2. Owner's Agent or Submitter

Walter R. J. [Signature]

Address Box 62

Napoleon Tel. 972-0966

3. Plans Prepared By:

A. Architect

B. Engineer

C. Other

4. Name of Job and Description of Building, Store, Church, Etc.

Storage Building for Feenz & Glick

5. Location of Project: [Address] Zone:

Lot # Subdivision Section

Yard Set Back: Front Rear

Side Side

6. Building Information:

Commercial Industrial New Construction

Addition Remodel

Size: Length 96 Width 66 No. of Stories ONE

Total Square Ft. Per Floor 6336

7. Additional Information: Bldg shall be constructed within the city

setback lines appeared by the end of working approval 9/26/78

Signature of Applicant [Signature] Date 10-9-78

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

ELECTRICAL PLAN APPROVAL

(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA.
FOR ENGINEERING OFFICE USE ONLY.

App. No. 179-78

Date Received 10-9-78

Received By R.E.F.

Estimated Cost 30,000

Minimum Fees

A. Structural \$18.00

B. At .55¢ Per 100 Ft.² 35.20

A. plus B. \$53.20

1. Owner's Name Paul Feuz & J. Glick

Address 27 W. Washington

Tel. 597-0961 (Glick)

2. Owner's Agent or Submitter

Address Box 62

Tel. 597-0966

3. Plans Prepared By:

A. Architect

B. Engineer

C. Other

4. Name of Job and Description of Building, Store, Church, Etc.

5. Location of Project: Blvd 1412 N. Scott Napoleon Zone:

Lot # Subdivision Section

6. Building Information:

Commercial Industrial New Construction

Addition Remodel

7. Size: Length 76 Width 66

Total Square Ft. Per Floor 26236

8. Size Service Entrance 400V Service Amp.

9. All electrical wiring shall be installed in accordance with the National Fire Protection Association, Bulletin No. 13, "National Electrical Code". All wiring shall also conform to the requirements of the Ohio Building Code for the occupancy indicated.

10. Additional Information:

Signature of Applicant Paul Feuz Date 10-9-78

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - Plan Examiner

