



City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151
NAPOLEON, OHIO 43545-0151
(419) 592-4010
FAX (419) 599-8393

October 21, 1996

Mayor
Donald M. Stange

Mr. Terry Michaelis
Proteam Corvette Sales Inc.
1410 N. Scott
Napoleon, Ohio 43545

Members of Council
Michael J. DeWit, President
Sarah J. Peper
John E. Church
James Hershberger
Terri A. Williams
Travis B. Sheaffer
Dennis Filgor

Re. Dump Site at 2296 N Scott

Dear Mr. Michaelis

NOTICE

City Manager
Marc S. Gerken, P.E.

Finance Director
Gregory J. Heath

Law Director
David M. Grahn

City Engineer
Adam C. Hoff, P.E.

In review of the subject dump site it would appear that it has been mismanaged to a certain degree. On October 15, 1996, I visited the site and discovered that the user of said has not followed the rules of general practice. Namely failure to properly layer and cover wood and other combustible materials. Proper layering is defined generally as two (2) feet maximum of combustible materials with a minimum dirt cover of three (3) feet. The site as observed on said date exhibited many uncovered loads of combustible materials. This is simply unacceptable and must not continue.

In the event you allow this practice to continue the City will need to intervene and take such action as is necessary to remedy said situation.

If you have questions or concerns regarding this notice please call me at 592-4010. Thank you in advance for your cooperation in this matter.

Sincerely

Brent N Damman
Building & Zoning
Administrator