

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 5-8-75

Permit No.

Type of Inspection Electrical

Type of Occupancy BB-73

Project Name Petrol Express

Address 1413 W Scott St

City Napoleon State Ohio

Approved

Violation

Electrical Contractor

Remarks:

Code Reference

~~Provide seals in hazardous locations where required in compliance with Article 511-6 (a & b)~~

Completed 5/12/75  
Re-inspected by JMF

Compliance Time Prior to opening

Inspectors Signature M. Howell

Copies To: Clarke and Spitzer

ENGINEERING DEPARTMENT

INTEROFFICE COMMUNICATION

Date 4/11/75

To: Engineering

From: Tom Terranova

Subject: Re-Opening Existing Gas Station in "PB" Zone

RE: 1417 N. Scott. St.  
New Owner Chuck Clarke  
Delta, O. 822-5947

Existing Bldg Permitted Use Under  
Sec. 85.11 Because Conditional Use  
CONFORMING.

Mr. Patton Prior owner informed  
me lot size is  $\frac{3}{4}$  Acre within

mins requirements,  
- No storage of trucks or trailer for hauling purposes  
Also not subject to Board Approval  
because of section 85.18

Gen. Provisions No. 9.

- No Alterations required to Existing Bldg.

Tom Terranova

- Need Sign Permits

Mr. Patton informed me Bldg was used for  
gas station up to May of 73, and has not  
been used for any other purpose since then.

- Subject to BB-73 of ABC.