

City of Napoleon
Engineering Department
P. O. Box 151 - 255 W. Riverview Ave.
Napoleon, Ohio 43545

No. 108-78

Date 8-24-78

CERTIFICATE OF

- Structural Plan Approval
- Electrical Plan Approval
- Special Plan Approval

Submitted

By: Napoleon Associates
Suite 1102, Twin Towers
99 Washington Ave.
Albany, New York

- Architect
- Engineer
- Other

- New
- Addition
- Alteration
- Mixed Occupancy
- Change of Occupancy

NAME AND LOCATION OF JOB

OWNER'S AGENT

| | |
|--|---------------|
| SHOPPING CENTER 1419 N. Scott St. Napoleon, Ohio 43545 | Same as above |
|--|---------------|

TYPE OF CONSTRUCTION (Where Applicable) II-C

O.B.C. Type of Occupancy 4101:2-67 Stories 1 Basement none

Approval for IGA supermarket.

Inspections shall be called for by the builder 48 hours in advance before work is covered. Final inspection must be made before building can be used or occupied. THIS CERTIFICATE SHALL REMAIN POSTED IN A CONSPICUOUS AND SAFE PLACE UNTIL COMPLETION OF JOB. APPROVED PLANS MUST BE KEPT ON JOB SITE AT ALL TIMES DURING CONSTRUCTION.

Plans, specifications and/or application as described above are hereby approved with addendum.

Date of Approval 8-24-78

BY: Norman Howes
PLAN EXAMINER

This approval does not cover the water supply, plumbing and drainage. Plans and specifications for this class of work shall be submitted to the Division of Plumbing, State Department of Health for examination and approval. For approval of pressure piping, contact the Division of Pressure Piping, 2323 W. Fifth Ave., Columbus, Ohio. Zoning for Napoleon is not included in this approval.

September 1, 1978

ADDENDUM TO PLAN APPROVAL

#108-78

I.G.A.

1. Particular attention is directed to Article 410-16 Paragraph (b), Fixture support from suspended ceilings.
2. Emergency circuitry required, Article 700-6 (d) N.E.C.

Norman Howes
City of Napoleon
Electrical Safety Inspector