

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 68-79 Issued 6-9-79
date

Job Location 1419 N. Scott St.
address

Lot 2 Morrow Hinderer & Patton X
sub-div or legal discript

Issued by R. E. Johnson by A.T.
building official

Owner Napoleon Associates
name tel.

Address Albany, New York

Agent Jim Speiser & Sons Electric
builder-eng.-etc. tel.

Address Rt. 2 Nap, Ohio 599-1846

Description of Use Electric servie for sign

Residential _____
no. dwelling units

Commercial XXX Industrial _____

New XX Add'n. _____ Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 400.00

FEES	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	0		0
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			0
LESS MIN. FEES PAID _____ <small>date</small>			0
BALANCE DUE.....			0

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: 30 A sign servie and 2 circuits.
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: _____

Date 6-11-79 Applicant Signature John P. Speiser
owner-agent

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date 6-9-79
~~6-8-79~~

Permit No. 68-79
~~68-79~~

Type of Inspection SIGN SERVICE

Type of Occupancy SHOPPING CENTER

Project Name NAPOLEON SHOPPING CENTER

Address 1419 N. SCOTT ST

City NAPOLEON State OH.

Approved ✓

Violation _____

Electrical Contractor SPEISER

Remarks:

Code Reference

NORM: THIS IS FOR THE SIGN AT THE ROAD

John Speiser - needs a ground
connected to line side of neutral bus
He was present when this inspection
was made. He is aware & will comply

Compliance Time _____

Inspectors Signature M.H.

Copies To: _____

AT

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name V/L PROJECT Address W.V.

Electrical Contractor Jim Spisak & Son's Elect Telephone No. 599-1846

Address RR#2 Nap. O

General Contractor NONE Telephone No. _____

Address _____

Location of Project Shopping Center SCOTT ST Cost of Project 400⁰⁰

Work Information:

Residential _____ Commercial L Industrial _____

No. Units _____
New V Service Change _____ Rewiring _____ Additional Wiring _____

Brief Description of Work: ENTRANCE & HOOKUP OF SIGN

Size of proposed Service Entrance 30A Number of new Circuits 2

Type of proposed Service Entrance _____ Underground _____ Overhead V

Require Temporary Electric _____ (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*GROUND-FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE; AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. Art. 210-8 N.E.C.

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date 6-5-79 Applicant's Signature John P. Spisak

68-79

PERMIT FEE \$ -0-