

APPLICATION FOR PERMIT TO TAP SEWER

(Print or Type)

Owner Napoleon Associates NO. S78-12
Address Suite 1102-Twin Towers 99 Washington Avenue BLDG. PERMIT 108-78
Albany, New York 12210
Contractor C. F. Gerken & Sons, Inc. PERMIT FEE \$ 30.00
Address 2296 N. Scott St. Nap. Ohio Tel. 592-3961 DATE PAID 7-6-78
for office use only

LOCATION OF CONNECTION

Street and No. N. Scott Street Sanitary XXX Storm _____
Lot No. 2 Subdivision Morrow, Hinderer, & Patton Size of Tap 6"
Size and Type of Sewer 6" PVC Hastic Pipe ALL WORK MUST BE INSPECTED

I certify that the sewer will be used only as indicated and no other Drainage will be connected.

Date _____ Signature _____ owner-builder-agent
do not write below this line

INSPECTION RECORD

Date Inspected July 11, 1978 Size and Type of Sewer 6" PVC PLASTIC
Location East side Scott St Depth 17.74' Type of Test Accepted Wind Test
Inspected and Approved By: Bruce Weirbach 7-12-78
Inspector Date
Additional Information _____

Send copy to: _____

SKETCH OF INSTALLATION

