

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 8-S Issued 5-15-79 date

Job Location 1419 N. Scott St. address

Lot 2 Morrow Hinderer & Patton

Issued By R.E. Johnson sub-div or legal discript
building official

Owner Save-Way Shoes name

Address 1419 N. Scott St. tel.

Agent Gardner Signs, Inc. no. dwelling units
builder-eng.-etc. tel. 385-6669

Address 3800 Airport Hwy, Toledo, Ohio

Description of Use Sign

Residential _____

Commercial XXX Industrial _____

New XXX Add'n. Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 800.00

	FEES	BASE	PLUS	TOTAL
<input type="checkbox"/>	BUILDING			
<input type="checkbox"/>	ELECTRICAL			
<input type="checkbox"/>	PLUMBING			
<input type="checkbox"/>	MECHANICAL			
<input type="checkbox"/>	DEMOLITION			
<input type="checkbox"/>	ZONING			
<input checked="" type="checkbox"/>	SIGN	\$4.00	15.00	\$19.00
	WATER TAP			
	SEWER TAP			
	TEMP. ELECT.			
	ADDITIONAL PLAN REVIEW		_____ hrs	
	TOTAL FEES.....			\$19.00
	LESS MIN. FEES PAID _____ date			0
	BALANCE DUE.....			\$19.00

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____
Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: _____ brief description

Plumbing: _____ brief description

Mechanical: _____ brief description

Sign: Wall Mounted Dimensions 4' x 20' Sign Area 80sq'

Additional Information: CALL FOR ELECTRICAL INSPECTION WHEN COMPLETE:

Date _____ Applicant Signature _____ owner-agent

INSPECTION RECORD

UNDERGROUND					ROUGH-IN					FINAL				
Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains		Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping					
	Water Piping		Water Piping			Condensate Lines			Backflow Prevention			Water Heater		
	Building Sewer													
	Sewer Connection											FINAL APPROVAL		
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Chimney(s) - 2-28			Grease Exhaust System					
			Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)					
			Ducts/ Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment					
			Duct Insulation			Pool Heater			Furnace(s)					
			Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL					
ELECTRICAL	Conduits & or Cable		Conduits/ Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting					
	Grounding & or Bonding		Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders					
	Floor Ducts Raceways		Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs					
	Service Conduit		Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance					
	Temporary Power Pole		Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL					
BUILDING	Location, Set-backs, Esmt(s)		Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector					
	Excavation					Exterior Lath			Demolition (sewer cap)					
	Footings & Reinforcing					<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard								
	Floor Slab		Interior Wall Construction			Fire Wall(s)			Building or Structure					
	Foundation Walls		Columns & Supports			Fireplace Chimney								
ADDITIONAL	Sub-soil Drain		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access								
	Piles		Floor System(s)			Special Insp Reports Rec'd			FINAL APPROVAL BLDG. DEPT.					
			Roof System						Certificate of Occupancy Issued					
						INSPECTIONS, CORRECTIONS, ETC.								
						INSPECTIONS, CORRECTIONS, ETC.								
					INSPECTIONS, CORRECTIONS, ETC.									
					INSPECTIONS, CORRECTIONS, ETC.									
					INSPECTIONS, CORRECTIONS, ETC.									
					INSPECTIONS, CORRECTIONS, ETC.									
					INSPECTIONS, CORRECTIONS, ETC.									

1.00 permit fee
18.00 electric fee
\$19.00 total

Include Electric Fee Also

Do Not Write Within Boxed Area.
For Engineering Office Use Only.
Permit No. 8-5
Issued
By
Estimated Cost \$800.00
Base Fee
Add
Total Fee \$19.00

CITY OF NAPOLEON
ENGINEERING DEPARTMENT

SIGN PERMIT

(Please Print or Type)

Owner's Name Sque-Way Shoes
Address Napoleon Plaza

Builder Gardner Signs, Inc Address 3800 AIRPORT HWY, TOLEDO, OHIO Tel. 385-6669

SIGN BILLBOARD AWNING MARQUEE

Location of Project: Front of Building

Additional Information: Single-faced, Plexiglas Internally Illuminated Facia Sign

Dimensions 4'x20' 80' sq Square Feet 80' sq
Date May 8, 1979 Signature of Applicant Peggy Barker - Gardner Sign Inc.

Application Must Be Accompanied with Sketch and Description of Proposed Installation

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - County Auditor

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - County Auditor

Application must be accompanied with sketch and description of proposed installation

Date March 8, 1953

Robert Barber - Designer
Signature of Applicant

Dimensions 4' x 20' 80' 28' Separate Feet 80' 28'

Additional Information: Sign for 616 Signs Intersecting Highway 21/2 mi

Location of Project: Front of Building

SIGN BILLBOARD WARNING MARQUEE

Builder Georgian Signs Inc Address 2800 Airport Hwy Torrey Calif Tel 392-9991

Address Napoleon Blvd

Owner's Name Signs Wld 2 phos

(Please Print or Type)

SIGN PERMIT Fee A120


ENGINEERING DEPARTMENT Electric

11100. Total
18.00 Special Fee
1.00 Permit Fee

CITY OF NAPOLEON

Total Fee	<u>A120</u>
Add	
Base Fee	
Estimated Cost	<u>\$ 300.00</u>
By	
Issued	
Permit No.	<u>8-13</u>

Do Not Write Within Boxed Area
For Engineering Office Use Only.



Napoleon Plaza

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name SAVEWAY SHOES

Address 1419 N. SCOTT

City NAP State OHIO

Approved

Violation

Electrical Contractor

Remarks:

E.C. John Spiers

*1) Door security system on time clock
acty with sighs. Time clock times
out door security system dont work
john has been notified.*

Elementary Electricity

Code Reference

26

Date 5-~~17~~-79

Permit No. 8-5

Type of Inspection SIGN.

Type of Occupancy STORE

SHOPPING CENTER

?

Compliance Time

Inspectors Signature

M. A

Copies To:

White - Applicant

Yellow - Engineering

Pink - Electrical Inspector

Copies To:

Compliance Time

Inspector's Signature

[Handwritten Signature]

[Large handwritten signature across the middle of the page]

Remarks: *1. Inspect the ground and bonding. 2. Check the panel and wiring. 3. Test the ground rod. 4. Check the panel for proper labeling. 5. Check the panel for proper grounding.*

Violation: *5* Electrical Contractor

Approved: *[Signature]*

City: *WHP* State: *OHIO* *STANDARD SERVICES*

Address: *1419 N. ZION* Type of Occurrence: *2506E*

Project Name: *SALISBURY STREET* Type of Inspection: *2706N*

(Please Print or Type)

255 Riverview Avenue Napoleon, Ohio 43545

ELECTRICAL INSPECTION FIELD REPORT

Engineering Department

CITY OF NAPOLEON

Type of Occurrence	<i>2506E</i>
Type of Inspection	<i>2706N</i>
Permit No.	<i>8-2</i>
Date	<i>2-18-18</i>
	<i>SK</i>

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name SAWELWAY STORES

Address 1419 N. SCOTT

City NAP State OHIO

Approved

Violation

Electrical Contractor

Remarks:

EC John Speers

*1. Door secured with lock on time clock
cater with sign. Time clock timer
and door security system don't work
John has been notified.*

Elementary Electrical

Code Reference

26

Date 5-27-79

Permit No. 8-5

Type of Inspection SIGN.

Type of Occupancy STORE

SHOPPING CENTER

?

Compliance Time

Inspectors Signature M. A

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name *SAVENWAY STORES*

Address *1419 N. SCOTT*

City *MAP* State *OHIO*

Approved

Violation

Electrical Contractor

Remarks:

Code Reference

EC John Spent
1. Does not work on time clock
city used sign time clock timer
and door security system door work
John has been notified
Elementary Electrical

26

Date *5-27-79*

Permit No. *8-5*

Type of Inspection *STGN.*

Type of Occupancy *STORE*

SHOPPING CENTER

Compliance Time

Inspectors Signature

M.A.

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

