

City Of Napoleon

FIELD SURVEY FORM

Premises Address: 1515 N Scott Company Name: Foster Canning
 Contact Name: Norm Harrison Contact Phone No: 592-7615
 Service No: 8563 Service Size: 8" Meter No: 4793449 Meter Size: 6" Date Installed: 1-11-93
 Type of Inspection: Initial Follow-Up Date of Inspection: 11-25-98 Inspector Name: Charlie
 Type of Use: Industrial Commercial Residential Water Main Size: 16" System Pressure 65-75psi
 Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
 If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
 Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
 Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
 Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
 Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity _____

INSPECTOR COMMENTS/DIAGRAMS

1 - Booster Pump for clean up 120psi
 5 - Feed Water Pumps for boilers w/ treatment 120psi usda approved for food
 2 - Water Softeners
 11 - Cookers no air gap on Dills
 2 - Cooling Tower Tanks no Air gap w/ treatment usda. Approved for food
 Tomato Wash line no air gap
 3 - Sanitizers w/ Chemical

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
 Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
 Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

BACKFLOW PREVENTION REQUIREMENTS

Depending on your water usage you will need either a 4" or 6"
 Reduced Pressure zone Assembly