# THE CITY OF NAPOLEON

## BUILDING & ZONING DEPARTMENT 255 W. RIVERVIEW (419)592-4010

Zoning Permit  Permit Number: ZP2009-3				Page 1 of 1 Printed: 3/2/201	
ADDRESS:		1825	1825 Scott St.		
Applicant Name: Address	Chan Zhou s: 260 W. Ervin Ro	d.	<b>Approval</b> 419-605	<b>Date:</b> 3/16/2009 -7690	
Owners					
Name:	Chan Zhou				
Address:	260 W. Ervin Rd				
	Van Wert, OH 4	5891			
Contracto	rs				
Fees and	Receipts:			A 1987-1989) HILL	
Numb	er	Description		Am	ount
			Total Fees:		\$0.00
			Total Receipts:	\$	0.00
Hong Kon	g Buffet - con	nmercial bldg.	Total Receipts:	\$	0.00
		nmercial bldg.		\$DATE:	0.00

## THE CITY OF NAPOLEON

### BUILDING & ZONING DEPARTMENT 255 W. RIVERVIEW (419)592-4010

WATER YOKE RELE	Page 1 of 1							
Permit Number: WT2	Printed: 4/1/2009							
ADDRESS:								
Applicant Name: Chan Zhou Address: 260 W Ervin Rd.		<b>al Date:</b> 4/1/2009 05-7690						
Owners								
Contractors								
Fees and Receipts:								
Number	Description	Amount						
	Total Fees	11.5.00						
	Total Receipts	\$10~0000 44730 \$6.00						
1 inch water meter upgrade from 5/8								
APPLICANTS SIGNATURE: Chan Zhou DATE: 4-1-								
REMINDER: YOU MUST CALL (419)592-4010 FOR AN INSPECTION								



Batch # 26463
ch# W 2009-1





\*



#### CITY OF NAPOLEON - OPERATIONS DEPT.

1775 Industrial Dr., Napoleon, OH 43545 Phone: 419/599-1891 FAX: 419/592-4379

#### Operations Superintendent Jeffrey C. Marihugh

Water Distribution Foreman Scott Damman

Streets/Sewer Foreman Ray Goodman

Construction Foreman Jeff Rathge

Maintenance Foreman Victor Pedraza

Refuse Foreman Todd Baldwin

Recycling Foreman Terry Nye

Head Mechanic Tony Kuhlman

# Memorandum

To:

Tom Zimmerman, Building and Zoning Inspector

CC:

Jon Bisher, City Manager

Scott Daman, Water Distribution Foreman Ray Goodman, Streets and Sewer Foreman

From:

Jeffrey C. Marihugh, Operations Superintendent

Date: March 12, 2009

Subject:

Plans for Hong Kong Buffet, 1825 North Scott

The Operations Department has reviewed the plans you provided on the above mentioned facility and have the following comments.

- 1. The facility shall be required to install a backflow device on the potable water line. A City of Napoleon Cross-Connection Control Questioner will need to be completed so the degree of hazard may be ascertained and the type of device required to be assigned.
- 2. A thermal expansion tank, which complies with current State of Ohio Plumbing Code and City of Napoleon Specifications, shall be installed on the plumbing.
- 3. No detailed plans were provided showing either the proposed water meter installation or the water meter sizing.
- 4. No plans were provided on the proposed backflow type, sizing and mounting location.
- 5. No detailed plans were submitted showing the thermal expansion installation.
- 6. While the drawings do show a 1,000-gallon grease trap, the proposed drawings show no baffling for the tank. Further, the City of Napoleon Water and Sewer Rules, Rule 19.2 (1) states that no discharge shall be more than 150° F. Neither the tank sizing nor the information on the proposed location provides documentation that the maximum or lower discharge temperature will be attained.

Should you have any questions on these comments, do not hesitate to contact me.