

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 1865 N. SCOTT ST. N. OLNEY ZIP: _____
 Business Name: R-G PROPERTIES / Rent-A-Center

DEVICE INFORMATION

Type (circle one) RP **DC** VB RPDA DCDA

Manf/Model: AMES / 3000S8F Size: 4 Serial No. 000250901

Location of Device: REAR STOCK ROOM

Type of Test: Differential Gauge Sight Tube

Outlet valve holding RP <input type="checkbox"/> DC <input checked="" type="checkbox"/> failed RP <input type="checkbox"/> DC <input type="checkbox"/>	Reduced Pressure Assembly ↓			Pressure Vacuum Breaker	
	Double Check Valve ↓		Relief Valve ↓	Air Inlet	Check Valve
	1st Check	2nd Check			
Test Results	DC <u>2.0</u> psi RP _____ psi	DC <u>2.0</u> psi	opened at _____ psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date: <u>3-26-03</u>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials					
Test After Repairs	DC _____ psi RP _____ psi	DC _____ psi RP _____ psi	opened at _____ psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date:	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: Danny Swisher Certification No. 2539
 Owner/Representative Signature: _____