

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 1865 N. Scott ZIP: 43545
 Business Name: Rent-a-Center fireline

DEVICE INFORMATION

Type (circle one) RP **(DC)** VB RPDA DCDA

Manf/Model: Ames 3000 SSF Size: 4 Serial No. 2000250901

Location of Device: Rear N.W. Corner

Type of Test: Differential Gauge Sight Tube

Outlet valve holding RP <input type="checkbox"/> DC <input checked="" type="checkbox"/> failed RP <input type="checkbox"/> DC <input type="checkbox"/>	Reduced Pressure Assembly ↓			Pressure Vacuum Breaker	
	Double Check Valve ↓		Relief Valve ↓	Air Inlet	Check Valve
	1st Check	2nd Check			
Test Results <i>Pass</i>	DC <u>2.5</u> psi RP _____ psi	DC <u>2.7</u> psi RP _____ psi	opened at _____ psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date: <i>3-31-04</i>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials					
Test After Repairs	DC _____ psi RP _____ psi	DC _____ psi RP _____ psi	opened at _____ psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date:	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: *[Signature]* Certification No. 2539

Owner/Representative Signature: *[Signature]*