



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

February 17, 1987

TRAILER PARK  
500 BLOCK  
HOOVER RD

**Mayor**

Robert G. Heft

Joseph Goodell  
2246 N. Scott Street  
Napoleon, Ohio 43545

**Members of Council**

William Young, President  
Lawrence Haase  
James Hershberger  
Donald Stevens  
Donald Morford  
Steve White

Dear Mr. Goodell:

Please be advised that the following trailers electrical entrances do not meet acceptable electrical standards and Codes, A-9 thru A-15, B-10 thru B-18, C-2 thru C-9, D-1 thru D-8, and need to be replaced as soon as possible.

**City Manager**

Richard A. Hayward

The meter sockets in all locations and the main switch in most locations need to be replaced.

**Clerk-Treasurer**

Rupert W. Schweinhagen

Pursuant to this end, the Board of Public Affairs have taken action. That action will not allow the connection of service to any location that makes any changes to a service point, (Iename change, disconnection for any reason) that does not meet acceptable standards and codes. The service will then remain off until such time that the service has been upgraded. We will be supplying you with the meter sockets as always.

**Law Director**

Keith P. Muehlfeld

If you need any help or have any questions, please feel free to call.

Sincerely,

David F. Mullholand  
Electric Distribution  
Superintendent

DFM:skw