City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

	2250		. 1			
Property Address.	2755 Sc. T ST			on Ohio	Zip: 43545	
Business Name:		Post 1313				
Contact Person:	Art Burdit	f		Title: Truste	24	
Phone Number	592-4868		Date of Test: 4 - 13 - 99			
DEVICE INFORMATION						
Type (circle one)	RP	DC	VB	RPDA	(DCDA)	
Manf/Model:	WATTS 0	07 MZ	Size: 3/4	Serial No.: 95	018	
Location of Device: Rise Room						
Type of Test.	Differential Gauge		Sight Tube			
Outlet	Reduced Pressure Assembly			Pressure Vacuum Breaker		
Valve					X ,	
Holding #	Double Check Valve		Relief Valve	Air Inlet	Check Valve	
Failed	1st Check	2nd Check				
Test	DC 10 psi	DC 10 psi	Opened at	Opened at	Held at	
Results 1,55			psi	psi	psi	
1000	Apparent					
	RPpsi					
	Actual		Did Not	Did Not	Leaked	
	RPpsi		Open	Open		
Date: 4.13.99	Pass 💹	Pass 🛎	Pass	Pass 🗆	Pass 🗆	
0 //	Failed	Failed	Failed	Failed	Failed	
Repairs &						
Materials						
				A CONTRACTOR OF THE PARTY OF TH		
		A SEA MINE .	Opened At	Opened At	Held At	
Test After	DC psi	DC psi	psi	psi	psi	
Repairs	•		Did Not	Did Not	3	
	RP psi	RP psi	Open	Open	Leaked	
	-					
Date:	Pass 🗆	Pass	Pass	Pass	Pass 🗆	
	Failed	Failed	Failed	Failed	Failed	
-		L	I TO TO THE TOTAL TOTAL TO THE		1	
Tester Signature: A My SA Comunal Certification No. 3035						
Owner/Representative Signature						