City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address:	2250 N.S	cott			Zip: 43545
Business Name: Amvets					
Contact Person: A	Art Burditt			Title: TrusTee	
Phone Number: 592-4868 Date of Test: 6-26-80					
DEVICE INFORMATION					
Type (circle one)	RP	DC	VB	RPDA	DCDA
Manf/Model: Wa	ts 007 m	2	Size: 3/4	Serial No.: 950	18
Location of Device: Plumbing closeT					
Type of Test: Differential Gauge 🖾 Sight Tube 🗆					
Outlet	Reduced Pressure	Assembly		Pressure Vacuum Breaker	
Valve					
Holding 🗹	Double Check Valve		Relief Valve	Air Inlet	Check Valve
Failed	1st Check	2nd Check	J		
Test A	DC 10 psi	DC 10 psi	Opened at	Opened at	Held at
Results Pass			psi	psi	psi
	Apparent				
	RP psi				
	Actual	**	Did Not	Did Not	Leaked
	RP psi		Open	Open	
Date:	Pass 🗷	Pass 🖾	Pass	Pass 🗆	Pass 🗆 "
6-26-00	Failed	Failed	Failed	Failed	Failed
Repairs &					
Materials					
			Opened At	Opened At	Held At
Test After	DC psi	DC psi	psi	psi	psi
Repairs			Did Not	Did Not	
	RP psi	RP psi	Open	Open	Leaked
Date:	Pass	Pass	Pass	Pass 🗆	Pass
	Failed	Failed	Failed	Failed	Failed
Tester Signature: Legether Junter Certification No. 2539					
Owner/Representative Signature: Andrew Surg Rende Sto					
The state of the s					