## City of Napoleon

## BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 2250 N. Scott 57. ZIP: 43545 Business Name: Amuets Post 1313					
Type (circle one) RP DEVICE INFORMATION DC VB RPDA DCDA					
Manf/Model: Wilking 975 XL Size: 2' Serial No. 472202  Location of Device: In Sprinkler System Room  Type of Test: Differential Gauge Sight Tube					
Outlet valve	Reduced Pressure Assembly   ↓			Pressure Vacuum Breaker	
holding  RP DC	Double Check Valve		Relief Valve	Air Inlet	Check Valve
failed RP DC	1st Check	2nd Check	Ĥ		
Test Results	DCpsi	DCpsi	opened at	opened atpsi	held atpsi
Pass	RP 81 psi		did not open □	did not open □	leaked
Date: 100	Pass 🖺 Failed 🗆	Pass	Pass □ Failed □	Pass □ Failed □	Pass   Failed
Repairs & Materials					
Test After	DC psi	DC psi	opened at psi	opened at psi	held at psi
Repairs	RPpsi	RPpsi	did not open □	did not open	leaked
Date:			*		
Date.	Pass □ Failed □	Pass  Failed	Pass  Failed	Pass □ Failed □	Pass  Failed
Tester Signature: Della L. Sunha Certification No. 2537  Owner/Representative Signature: Wayner					

Water Dist. - White Building Dept. - Canary

Customer - Pink

Tester - Goldenrod