



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

May 08, 1991

Lee Short, A.I.A.
217-1/2 N. Defiance
Archbold, Ohio 43502

Re: AMVETS
N. Scott Street

1431

Dear Mr. Short:

We have enclosed a sketch of the existing drainage infrastructures near the above referenced facility.

It is our understanding that the Amvets are planning a building addition and it is your intent to discharge your roof water (from this new addition) into this system.

As you can see from the attached sketch, there does exist a 12" storm sewer which outlets into the ravine just south of your project.

We have reviewed this situation and based on the conditions that exist feel that no direct tie into this line for roof water drainage should be made.

This 12" line handles a considerable amount of surface water currently and by allowing additional direct runoff we feel problems will start to compound.

Please note, that the Amvets should be aware that if they ever plan to improve (pave) the back stoned area, that the City of Napoleon will require an improved drainage system to handle this water.

Mayor
Steven Lankenau

Members of Council
James Hershberger, President
Terri A. Williams
John E. Church
Randy J. Bachman
Dennis L. Filgor
Robert G. Heft

City Manager
Terry Dunn

Finance Director
Rupert W. Schweinhagen


Law Director
Michael J. Wesche

Prosecuting Attorney
Thomas L. Blschoff

Therefore, this may be the time to decide what future planning and/or drainage improvements need to be made.

If you have any questions, please call.

Respectfully,



Marc S. Gerken, P.E.
City Engineer

MSG:rw

Enclosure

cc: Sonny Helberg
Brent Damman

Top of M.H. Survey
Sta. 32+29.30
Elev. 684.46

