

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 10-16-75

Permit No. [redacted] 19-75S

Type of Inspection ELECTRICAL

Type of Occupancy

Project Name SERVICE Station Supply Co

Address 2250 N SCOTT ST

City Napoleon State OHIO

Approved

Note: Free Standing sign on Southwest Side.

Violation Electrical Contractor Harmon Sign Co.

Remarks: Code Reference

1. NM MINIMIZABLE ASSEMBLY'S ARE NOT SUITABLE FOR SPAN TYPE WIRING - THE CONDUCTORS MUST HAVE A MESSENGER WIRE WITH PROPER TERMINATIONS. Art. 225-13 NEC.

2. Where outside branch or feeder circuits leave or enter a building, the requirements of Art. 230-43, 230-52 & 230-54 shall apply. Art. 225-11 NEC

3. Grounding connection to electrode shall be connected with suitable fitting. Art. 250-115 NEC

Must contact Engineering Dept For Re-inspection.

Compliance Time ad once Inspectors Signature Howes

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

11/26/75 Inspected & Approved by Howes