

**City Of Napoleon**  
**FIELD SURVEY FORM**

Premises Address: 2250 N. Scott St. Company Name: Amvets Post 1313  
Contact Name: Art Burditt Contact Phone No: 592-4868  
Service No: 9783 Service Size: 2" Meter No: 70023368 Meter Size: 2" Date Installed: 6-3-97  
Type of Inspection: Initial  Follow-Up  Date of Inspection: 1-5-98 Inspector Name: Charlie  
Type of Use: Industrial  Commercial  Residential  Water Main Size: 6" System Pressure 65.75 psi  
Type of Service: Domestic  Fire  Combined  Any Other Water Source: Yes  No   
If Yes, Other Type: Additional City Service  Auxiliary Source  Interconnected: Yes  No   
\*\*\*\*\*

**DOMESTIC SYSTEMS**

Type of Use: Processing  Product  Potable  Sanitary  Irrigation  Limited Area Fire   
Type of Heating: Forced Air  Electric  Solar  Boilers  Chemical Treatment: Yes  No   
Type of Cooling: Cooling Tower  Chiller  Chemical Treatment: Yes  No  Direct Conn: Yes  No   
Dishwasher: Yes  No  Eductors: Yes  No  Garbage Disposal: Yes  No  Jacuzzi: Yes  No   
Swimming Pool: Yes  No  Air Gap at Supply: Yes  No  Pumps Used: Yes  No  Capacity \_\_\_\_\_

**INSPECTOR COMMENTS/DIAGRAMS**

*CO<sub>2</sub> To drinking fountains*

**FIRE PROTECTION SYSTEMS**

*6" Fireline Service # 8718      6" Watermain*  
System Type: Dry Sprinkler  Wet Sprinkler  Dry Riser  Wet Riser  Hydrants: Yes  No   
Hydrants Self-Draining: Yes  No  Storage Provided: Yes  No  Antifreeze Legs: Yes  No   
Auxiliary Water Storage: Yes  No  Pumps Used: Yes  No  Capacity: \_\_\_\_\_ (GPM) Pressure: \_\_\_\_\_

**INSPECTOR COMMENTS/DIAGRAMS**

*R.P.Z.A. is already in place on 2" service needs tested*

*D.C.D.A. on fire line needs tested*

**BACKFLOW PREVENTION REQUIREMENTS**