

Do Not Write Within Boxed Area.
For Engineering Office Use Only.

CITY OF NAPOLEON
ENGINEERING DEPARTMENT

SIGN PERMIT

(Please Print or Type)

PAID

Permit No. 00295
 Issued 2-2-87
 By \$1
 Estimated Cost 3000.00
 Base Fee 4.00
 Add 29.60
 Total Fee 37.60

Owner's Name Napoleon
 Address 2295 SCOTT ST. CITY OF NAPOLEON
 Address 2295 SCOTT ST. CITY OF NAPOLEON
 Address 2295 SCOTT ST. CITY OF NAPOLEON

Builder Casey Sun Co. Address 2295 SCOTT ST. CITY OF NAPOLEON Tel. 776-0542

SIGN BILLBOARD AWNING MARQUEE


Location of Project: 2295 SCOTT ST. NOTE: THE SIGN MAY BE TOO CLOSE TO THE

Additional Information: EXISTING UTILITY POLE. THE SIGNING WILL PAID

Dimensions 12' x 12' + 14' x 5' Date FEB 2 1987 Square Feet 572

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - County Auditor
 City of Napoleon Signature of Applicant Joe L. ...

Application Must Be Accompanied with Sketch and Description of Proposed Installation



CITY OF NAPOLEON
255 W. Riverview
NAPOLEON, OHIO 43545

message

reply

to

JOE WHELAN C/O CASEY OUTDOOR
ADVERTISING 9995 STICKNEY AVE
TOC, OHIO 43608

▲ FOLD

subject ENCLOSED FND YOUR RECEIPT
FOR PAYMENT OF \$22.60 FOR
SIGN PERMIT NO 00295

date 2-2-87

signed ELDON HUBER


date _____ signed _____

SENDER: Mail white and pink copies with carbon intact.

RECEIVER: Reply, retain white copy, return pink copy.

© 1982 Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

40' UTILITY POLE



NO CLOSURE TO ELEC LINES
THAN THE EXISTING SIGN

0395 1011

PROJECT RECORD FORM

JOB NUMBER _____

DATE	REMARKS
16 MAR 85	HOLIDAY INN IS AN R-1 NORTHCREST NURSING HOME IS AN I-2
	LSF SEC. 31-4.5 OBBC SEC. 1424.0 DECORATIVE MATERIALS RESTRICTIONS
	NON-COMBUSTIBLE OR FLAMERESISTANT [REMOVED AND MAINTAINED] MATERIALS ARE REQUIRED IN THE NORTHCREST NURSING HOME AND NOT IN THE HOLIDAY INN
	Paul E. Bushner