

# THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419) 592-4010

---

## Zoning Variance Permit

Permit Number: ZV2008-8

Page 1 of 1

Printed: 8/1/2008

---

### ADDRESS:

*777 Scott St.*

---

### Applicant

**Name:** Circle K Great Lakes  
**Address:** 935 E. Tallmadge Ave  
Attn: Craig Domers  
Akron, OH 44310

**Approval Date:** 8/1/2008  
330-963-6100

---

### Owners

**Name:** Circle K Great Lakes  
**Address:** 935 E. Tallmadge Ave  
Attn: Craig Domers  
Akron, OH 44310

**Phone:** 330-963-6100

---

### Contractors


#### Fees and Receipts:

Number	Description	Amount
FEE2008-508	Zoning	\$50.00
<b>Total Fees:</b>		<b>\$50.00</b>
RCPT2008-311		\$50.00
<b>Total Receipts:</b>		<b>\$50.00</b>

A pressure backflow preventor w/expansion tank must be installed on the domestic water service.

APPLICANTS SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

**REMINDER: YOU MUST CALL (419)592-4010 FOR AN INSPECTION**



**Zoning Permit Only!**  
other permits may be required



Zoning Administrator  
Building Commissioner  
Tom Zimmerman

CITY OF NAPOLEON  
Building & Zoning Division  
255 W. Riverview Avenue, PO Box 151, Napoleon, OH 43545  
Phone: 419-592-4010 - Fax: 419-599-8393

# ZONING PERMIT APPLICATION

LOCATION OF <sup>Existing</sup> PROPOSED BUSINESS: 777 Scott Street

ZONE: \_\_\_\_\_

TYPE OF BUSINESS: Existing Circle K Convenience store and gas station.

PROPERTY OWNER: Circle K Great Lakes Athn. Craig Domers

PROPERTY OWNER ADDRESS: 935 E. Tallmadge Ave., Akron OH 44310

BUSINESS OWNER: Circle K Great Lakes Athn. Craig Domers

OWNER ADDRESS: 935 E. Tallmadge Ave., Akron OH 44310

OWNER PHONE: 330.963.6100 CELL: —

SQUARE FOOT OF BUILDING: 3,124 sq

NUMBER OF PARKING SPACES: 7

Susan Moore  
SIGNATURE OF APPLICANT

7/18/08  
DATE


.....  
OFFICE USE ONLY

APPROVED     NOT APPROVED     PENDING     SPECIAL/CONDITIONAL USE  
REQUIRED  
DATE OF MEETING: \_\_\_\_\_

\_\_\_\_\_  
TOM ZIMMERMAN  
ZONING ADMINISTRATOR

\_\_\_\_\_  
DATE

A Reduced pressure backflow preventor w/ expansion tank must be installed on the domestic water service.



3723 Pearl Road  
Cleveland, Ohio 44109  
(216) 749-7800 phone  
(216) 749-1300 fax  
www.arkinetics.com

Architecture  
Planning  
Interiors  
Preservation  
Urban Design



# Transmittal

**Arkinetics, Inc. Project #:** 08001.09

**Date:** 07/18/08

**To:** Napoleon Building Department

255 W. Riverview  
Napoleon, Ohio 43545

**Phone:** 419.592.4010

**Re:** Circle K Convenience Store

Store #5641

777 Scott Street

Napoleon, OH 43545

**Attn:** Tom Zimmerman

**Please find:**  Enclosed  Under separate cover the following:

**Description:**

Prints: G-101, D-101, A-101, A-102, A-103, P-101, P-102, M-101, E-101, E-102 and E-103  
Building Permit Application  
Permit Application Fee – Check \$50.00

**Copies:**

1 set  
1  
1

**These have been sent via:** Fed Ex

**If enclosures are not as listed, please notify us immediately.**

**Comments:**

Issued for permit set.  
Please call if you have any additional questions or require additional information.

**From:** Arkinetics, Inc.

Susan Moore, Project Architect

**Copy to:** File

SUSAN@ARKINETICS



## CITY OF NAPOLEON - OPERATIONS DEPT.

1775 Industrial Drive • Napoleon, OH 43545

Ph. (419) 599-1891 • Fax (419) 592-4379

May 21, 2008

Operations Superintendent  
Jeffrey C. Marihugh

Water Distribution Foreman  
Scott Damman

Streets / Sewer Foreman  
Ray Goodman

Construction Foreman  
Jeff Rathge

Maintenance Foreman  
Victor Pedraza

Refuse Foreman  
Todd Baldwin

Recycling Foreman  
John Babcock

Head Mechanic  
Tony Kuhlman

Re: Cross-connection Control Survey At: Mac's Convenience  
dba Circle K  
777 Scott St.  
Napoleon, OH

During its meeting of April 15, 1972, the Public Health Council of the Department of Health, State of Ohio, adopted new regulations EP-5-01 to EP-5-10 inclusive, relative to backflow prevention and cross-connection control in public water systems to the Ohio Sanitary Code. These regulations, which became effective July 1, 1972, were adopted by the Ohio Environmental Protection Agency (OEPA) as Chapters 3745-95 of the Ohio Administrative Code and affect both new and existing services. Due to stepped up enforcement by the OEPA, the City is now required to implement this program.

On October 20, 1997, the City Council of Napoleon passed Ordinance Number 82-97 providing for water quality protection and cross-connection control.

In compliance with the above laws and regulations, the City of Napoleon Water Distribution Department is required to make periodic surveys and investigations of water use practices within the consumer's premises. The purpose of these surveys is to determine whether there are actual or potential cross-connections through which contaminants could backflow into the public water system and, if necessary to prescribe the type of backflow prevention required.

*I would like to meet with you or your representative within the next thirty (30) days for this purpose.* Please call me at 419/599-1891 Monday through Friday, between the hours of 7:00 a.m. and 3:00 p.m. to make arrangements.

Sincerely,

Scott Damman,  
City of Napoleon  
Water Distribution Foreman

SD/tlc