

City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151
NAPOLEON, OHIO 43545-0151
(419) 592-4010
FAX (419) 599-8393

May 17, 1996

Mr. John Helberg, P.E.
Gerken Paving, Inc.
P.O. Box 607
Napoleon, Ohio 43545

Mayor
Donald M. Stange

Members of Council
Michael J. DeWit, President
Sarah J. Peper
John E. Church
James Hershberger
Terri A. Williams
Travis B. Sheaffer
Dennis Filgor

City Manager
Marc S. Gerken, P.E.

Finance Director
Gregory J. Heath

Law Director
David M. Grahn

City Engineer
Adam C. Hoff, P.E.

Re: Snyder-Wesche Funeral Home
Parking Lot Improvements

Dear Mr. Helberg:

As per our telephone conversation of May 15, 1996, please lower the proposed ten (10) inch storm sewer to provide a minimum of 4'-0" of cover, relocate the catch basin to the west to reduce the slope of the asphalt and limit the placement of the stone base to no nearer than 20'-0" from the easterly right-of-way of Scott Street. With these revisions, your plan is hereby approved.

The remaining issues stated in my correspondence of May 1, 1996 will need to be addressed by the Board of Zoning Appeals and Planning Commission at a later date prior to the installation of the proposed fencing and parking stalls.

If you should have any questions, please call me.

Yours truly,



Adam C. Hoff, P.E.
City Engineer

ACH:rd

cc: Mr. Richard Borris
Mr. Brent Damman, Building/Zoning Inspector
Mr. Sonny Helberg, Construction Inspector

C:\AMIPRO\CITYENGR\LETTERSHELBERG.SAM May 17, 1996 8:33 AM