



# City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151  
NAPOLEON, OHIO 43545-0151  
(419) 592-4010  
FAX (419) 599-8393

*840 Scott*

May 17, 1996

Mr. John Helberg, P.E.  
Gerken Paving, Inc.  
P.O. Box 607  
Napoleon, Ohio 43545

Mayor  
Donald M. Stange

Members of Council  
Michael J. DeWit, President  
Sarah J. Peper  
John E. Church  
James Hershberger  
Terri A. Williams  
Travis B. Sheaffer  
Dennis Fligor

City Manager  
Marc S. Gerken, P.E.

Finance Director  
Gregory J. Heath

Law Director  
David M. Grahn

City Engineer  
Adam C. Hoff, P.E.

Re: Snyder-Wesche Funeral Home  
Parking Lot Improvements

Dear Mr. Helberg:

As per our telephone conversation of May 15, 1996, please lower the proposed ten (10) inch storm sewer to provide a minimum of 4'-0" of cover, relocate the catch basin to the west to reduce the slope of the asphalt and limit the placement of the stone base to no nearer than 20'-0" from the easterly right-of-way of Scott Street. With these revisions, your plan is hereby approved.

The remaining issues stated in my correspondence of May 1, 1996 will need to be addressed by the Board of Zoning Appeals and Planning Commission at a later date prior to the installation of the proposed fencing and parking stalls.

If you should have any questions, please call me.

Yours truly,

Adam C. Hoff, P.E.  
City Engineer

ACH:rd

cc: Mr. Richard Borris  
Mr. Brent Damman, Building/Zoning Inspector  
Mr. Sonny Helberg, Construction Inspector

C:\AMIPRO\CITYENGR\LETTERS\HELBERG.SAM May 17, 1996 8:33 AM