

Mail To:
Ron Harwell
230 Bridle Tr.
Lima, OH, 45807

City Of Napoleon FIELD SURVEY FORM

419-867-4640
Jeff Frazer

Premises Address: 904 N. Scott Company Name: Speedway
Contact Name: (above) Contact Phone No: (above) 419-592-1266
Service No: 9770 Service Size: 1" Meter No: 47339162 Meter Size: 1" Date Installed: 12-12-97
Type of Inspection: Initial Follow-Up Date of Inspection: 1-20-99 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 4" System Pressure 65-75 psi
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

soda fountain w/co2
coffee machine
Cappuccino machine
1- restroom
soap eductor for cleaning
kitchen sink

2 - sinks in utility
water filter system for fast food bar
ice maker

FIRE PROTECTION SYSTEMS

System Type: Dry Sprinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: (GPM) Pressure:

INSPECTOR COMMENTS/DIAGRAMS

already has 1" RPZA in place is sufficient
expansion tank already in place

BACKFLOW PREVENTION REQUIREMENTS

This device needs to have a drain pipe installed to floor drain or other drain, and be made accessible for testing